

**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

August 12, 2010

Ms. Amy Ammon, General Manager
Biederman Educational Centers, Inc.
P.O. Box 488020
Cincinnati, Ohio 45211

Re: Hamilton County, Biederman Educational Center, Notice of Violation

Dear Ms. Ammon:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of May 2009 through August 2009 for the Biederman Educational Center. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0112461; OEPA Permit # 1PZ00051*BD). The specific instances of noncompliance are as follows:

Effluent Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
December 2009	Ammonia	30D Conc	3.0	6.1	12/1/2009
December 2009	Ammonia	1D Conc	4.5	19	12/2/2009
March 2010	TSS	1D Conc	18	31	3/1/2010
March 2010	TSS	30D Conc	12	44	3/1/2010
March 2010	CBOD	30D Conc	10	11	3/1/2010
March 2010	TSS	1D Conc	18	52	3/2/2010
March 2010	TSS	1D Conc	18	49	3/3/2010
June 2010	Ammonia	1D Conc	1.5	5.3	6/1/2010
June 2010	Ammonia	30D Conc	1.0	5.0	6/1/2010
June 2010	Chlorine	1D Conc	0.019	0.070	6/1/2010
June 2010	pH	1D Conc	6.5	6.3	6/1/2010
June 2010	Ammonia	1D Conc	1.5	3.7	6/2/2010
June 2010	Ammonia	1D Conc	1.5	5.9	6/3/2010


Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Ms. Amy Ammon
August 12, 2010
Page 2

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations. Future violations must be reported as required by the NPDES Permit as detailed in Part III, Item 12 "Noncompliance Notification."

If you have any questions regarding this matter please feel free to contact me at (937) 285-6107 or via email at: Robert.Ostendorf@epa.state.oh.us.

Sincerely,



Bob Ostendorf Jr.
Division of Surface Water
Permit Section

cc: Mr. John Beckman, Beckman Environmental