



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 8, 2009

Tim Brennan
Brennan Electric
P.O. Box 266
Miamitown, Ohio 45401

RE: NOTICE OF VIOLATION
Brennan Electric
6859 Cemetery Road
NPDES Permit 11N00249*BD

Dear Mr. Brennan:

I have reviewed your self-monitoring reports for the months of January through August of 2009, for the discharge outfall 001 from the wastewater treatment system. The review indicates the following effluent limit violations of the NPDES permit for this facility.

EFFLUENT LIMIT VIOLATIONS AT OUTFALL 001

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Chlorine, T. R.	6/12/2009	0.019 mg/l	0.16 mg/l
Dissolved Oxygen	8/21/2009	6.0 mg/l	4.1 mg/l
Chlorine, T. R.	8/21/2009	0.019 mg/l	0.25 mg/l
Nitrogen, Ammonia	8/2009	1.0 mg/l	1.1 mg/l

Our office did not receive any non-compliance notifications for these violations which are required under the permit in Part III, item 12.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. You are required to respond to this letter within 10 days of receipt of this letter. Your response should indicate what caused the non-compliance and the actions you will take to comply with the requirements of the NPDES permit.

Tim Brennan
October 8, 2009
Page 2

It is my understanding that public sanitary sewers are now available in Miamitown. Have you contacted the Metropolitan Sewer District and/or the Whitewater Township Regional Sewer District to make arrangements for the tap or sewer extension?

If you have any questions regarding this letter, please contact me at (937) 285-6101 or at my email address mary.osika@epa.state.oh.us.

Sincerely,

A handwritten signature in black ink, appearing to read "Mary Osika", with a long horizontal flourish extending to the right.

Mary Osika
Environmental Specialist
Division of Surface Water

cc: D. Feichtner, National Wastewater Industries