



State of Ohio Environmental Protection Agency

**Southwest District Office**

401 E. Fifth St.  
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korfesi, Director

April 22, 2009

Mr. Doug Evans  
Evans Landscaping, Inc.  
4229 Roundbottom Road  
Cincinnati, Ohio 45244

**Re: Broadwell Factory Group, LLC  
Property at 8485 Broadwell Road  
NPDES Permit No. 1IS00003\*DD; OH0046493  
Notice of Violation**

Dear Mr. Evans:

We have reviewed your self-monitoring reports covering the months of January, 2007 through March, 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit. The specific instances of noncompliance are listed in the enclosed table.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6102 or by electronic mail at [Mike.Zimmerman@epa.state.oh.us](mailto:Mike.Zimmerman@epa.state.oh.us)

Respectfully,

Mike Zimmerman  
Environmental Specialist II  
Division of Surface Water

**FINAL EFFLUENT LIMIT VIOLATIONS (Outfall 001)**  
**(Period of Review: January 2007 – March 2009)**

7D = Weekly 30D = Monthly 1D = Daily Conc. = Concentration (mg/l) Qty. = Quantity (Kg/Day)

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2007	Nitrogen, Ammonia (NH3)	30D Conc	2.0	18.85	2/1/2007
February 2007	Nitrogen, Ammonia (NH3)	30D Qty	0.0757	.68281	2/1/2007
February 2007	Nitrogen, Ammonia (NH3)	1D Conc	3.0	35.	2/21/2007
February 2007	Nitrogen, Ammonia (NH3)	1D Qty	0.114	1.32475	2/21/2007
March 2007	Nitrogen, Ammonia (NH3)	30D Conc	2.0	12.1	3/1/2007
March 2007	Nitrogen, Ammonia (NH3)	30D Qty	0.0757	.14345	3/1/2007
March 2007	Nitrogen, Ammonia (NH3)	1D Conc	3.0	21.	3/7/2007
March 2007	Nitrogen, Ammonia (NH3)	1D Qty	0.114	.23846	3/7/2007
March 2007	Nitrogen, Ammonia (NH3)	1D Conc	3.0	3.2	3/21/2007
March 2007	pH	1D Conc	6.5	6.4	3/21/2007
April 2007	pH	1D Conc	6.5	6.3	4/4/2007
April 2007	pH	1D Conc	6.5	6.4	4/11/2007
April 2007	pH	1D Conc	6.5	6.4	4/25/2007
May 2007	pH	1D Conc	6.5	6.4	5/2/2007
May 2007	pH	1D Conc	6.5	6.3	5/16/2007
May 2007	pH	1D Conc	6.5	6.4	5/24/2007
May 2007	pH	1D Conc	6.5	6.4	5/30/2007
June 2007	pH	1D Conc	6.5	6.3	6/6/2007
June 2007	pH	1D Conc	6.5	6.3	6/13/2007
June 2007	pH	1D Conc	6.5	6.4	6/27/2007
July 2007	pH	1D Conc	6.5	6.4	7/17/2007
August 2007	pH	1D Conc	6.5	6.4	8/16/2007
August 2007	pH	1D Conc	6.5	6.4	8/21/2007
February 2008	Nitrogen, Ammonia (NH3)	30D Conc	2.0	6.05	2/1/2008
February 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.0757	.12604	2/1/2008
February 2008	Nitrogen, Ammonia (NH3)	1D Conc	3.0	9.1	2/5/2008
February 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.114	.20666	2/5/2008
March 2008	Nitrogen, Ammonia (NH3)	30D Conc	2.0	4.85	3/1/2008
March 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.0757	.21064	3/1/2008
March 2008	Nitrogen, Ammonia (NH3)	1D Conc	3.0	8.	3/4/2008
March 2008	Nitrogen, Ammonia (NH3)	1D Qty	0.114	.36336	3/4/2008
June 2008	Chlorine, Total Residue	1D Conc	0.019	.08	6/10/2008
August 2008	Nitrogen, Ammonia (NH3)	30D Conc	2.0	2.19	8/1/2008
August 2008	Nitrogen, Ammonia (NH3)	1D Conc	3.0	4.2	8/5/2008
February 2009	Nitrogen, Ammonia (NH3)	30D Conc	2.0	4.85	2/1/2009
February 2009	Nitrogen, Ammonia (NH3)	1D Conc	3.0	5.5	2/3/2009
February 2009	Nitrogen, Ammonia (NH3)	1D Conc	3.0	4.2	2/17/2009
March 2009	Nitrogen, Ammonia (NH3)	1D Conc	3.0	3.3	3/3/2009