



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

February 3, 2011

Mr. Tom Weller  
Canterbury Row Condominium Association  
5944 Harrison Avenue  
Cincinnati, Ohio 45248

Re: Hamilton County, Canterbury Row Condominium Association, NPDES Permit Violations

Dear Mr. Weller:

The Ohio EPA has completed a compliance evaluation of the Data Monitoring Reports (DMR) covering the months of July through December 2010 for Canterbury Row Condominium Association. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0072109; OEPA Permit # 1PZ00008\*DD). The specific instances of noncompliance are as follows:

Frequency / Monitoring Violations						
Reporting Period	Parameter	Sample Frequency	Expected	Reported	Violation Date	
August 2010	Color	1/Day	1	0	08/03/2010	
August 2010	Color	1/Day	1	0	08/18/2010	
August 2010	Odor	1/Day	1	0	08/03/2010	
August 2010	Odor	1/Day	1	0	08/18/2010	
August 2010	Turbidity	1/Day	1	0	08/03/2010	
August 2010	Turbidity	1/Day	1	0	08/18/2010	
October 2010	Color	1/Day	1	0	10/12/2010	
October 2010	Odor	1/Day	1	0	10/12/2010	
October 2010	Turbidity	1/Day	1	0	10/12/2010	
November 2010	Color	1/Day	1	0	11/15/2010	
November 2010	Color	1/Day	1	0	11/16/2010	
November 2010	Color	1/Day	1	0	11/22/2010	
November 2010	Odor	1/Day	1	0	11/15/2010	
November 2010	Odor	1/Day	1	0	11/16/2010	
November 2010	Odor	1/Day	1	0	11/22/2010	
November 2010	Turbidity	1/Day	1	0	11/15/2010	
November 2010	Turbidity	1/Day	1	0	11/16/2010	
November 2010	Turbidity	1/Day	1	0	11/22/2010	

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is required at this time.




11

Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at [Robert.Ostendorf@epa.state.oh.us](mailto:Robert.Ostendorf@epa.state.oh.us).

Sincerely,

A handwritten signature in cursive script that reads "Bob Ostendorf Jr.".

Bob Ostendorf Jr.  
Division of Surface Water  
Permit Section



14