



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

July 2, 2007

Mr. Bob Havrilla
Joint Vocational School District
3254 East Kemper Road
Cincinnati, Ohio 45241

Re: Hamilton County, Diamond Oaks Career Development Center,
NPDES Permit Violations

Dear Mr. Havrilla:

We have reviewed your Monthly Operating Reports (MORs) covering the months of 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0047287; OEPA Permit # 1PT00050*ED). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations

| Reporting Period | Parameter | Limit Type | Units | Permit Limit | Reported Value |
|------------------|-----------|------------|-------|--------------|----------------|
| February 2007 | CBOD5 | Weekly | mg/l | 15 | 16.6 |
| February 2007 | Ammonia | Monthly | mg/l | 2.5 | 6.55 |
| February 2007 | Ammonia | Weekly | mg/l | 3.75 | 3.8 |
| February 2007 | TSS | Monthly | mg/l | 12 | 80.25 |
| February 2007 | TSS | Weekly | mg/l | 18 | 159. |
| February 2007 | Ammonia | Weekly | mg/l | 3.75 | 9.3 |
| February 2007 | TSS | Weekly | mg/l | 18 | 76.5 |
| March 2007 | Ammonia | Monthly | mg/l | 2.5 | 10.25 |
| March 2007 | Ammonia | Weekly | mg/l | 3.75 | 18.3 |
| March 2007 | DO | Daily | mg/l | 5.0 | 3.1 |
| March 2007 | DO | Daily | mg/l | 5.0 | 3.1 |
| March 2007 | pH | Daily | S.U. | 6.5 | 4.0 |
| April 2007 | pH | Daily | S.U. | 6.5 | 5.9 |
| April 2007 | pH | Daily | S.U. | 6.5 | 5.7 |
| April 2007 | pH | Daily | S.U. | 6.5 | 5.2 |
| May 2007 | pH | Daily | S.U. | 6.5 | 5.8 |
| May 2007 | pH | Daily | S.U. | 6.5 | 5.8 |



Mr. Bob Havrilla
July 2, 2007
Page 2

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports addressing the reasons for the February and March 2007 violations and the actions being taken to prevent further occurrences. However, the April and May 2007 violations have not been addressed. Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the April and May 2007 violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,



Laura Pohlman
Division of Surface Water
Permit Section

cc: Andy Griner, Winelco, Inc.