



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

June 2, 2009

Mr. Robert Havrilla,
V.P. Property and Assets
Diamond Oaks Career Development Center
6375 Harrison Avenue
Cincinnati, Ohio 45247

Re: Hamilton County, Diamond Oaks Career Development Center, NPDES Permit Violations

Dear Mr. Havrilla:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of December 2008 through June 2009 for the Diamond Oaks Career Development Center. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0047287; OEPA Permit # 1PT00050*ED). The specific instances of noncompliance are as follows:

Effluent Limit Violations						
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Units of Measure	Violation Date
January 2009	TSS	Weekly Conc.	3.41	4.26	mg/l	1/15/2009
January 2009	Ammonia	Monthly Conc.	2.5	4.4	mg/l	1/1/2009
January 2009	Ammonia	Weekly Conc.	3.75	6.60	mg/l	1/1/2009
January 2009	Ammonia	Monthly Qty	0.474	0.689	lbs.	1/1/2009
January 2009	Ammonia	Weekly Qty	0.71	1.3	lbs.	1/15/2009
December 2008	TSS	Weekly Conc.	18	26	mg/l	12/15/2008
December 2008	Ammonia	Monthly Conc.	2.5	4.1	mg/l	12/1/2008
December 2008	Ammonia	Weekly Conc.	3.75	5.60	mg/l	12/15/2008
February 2009	Ammonia	Monthly Conc.	2.5	3.1	mg/l	2/1/2009
February 2009	Ammonia	Weekly Conc.	3.75	6.10	mg/l	2/1/2009

Mr. Robert Havrilla

June 2, 2009

Page 2


Frequency / Reporting Violations					
Reporting Period	Parameter	Sample Frequency	Expected	Reported	Violation Date
December 2008	Temperature	1/Day	1	0	12/26/2008
December 2008	Color	1/Day	1	0	12/26/2008
December 2008	Odor	1/Day	1	0	12/26/2008
December 2008	Turbidity	1/Day	1	0	12/26/2008

Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations. Your response should include the dates, either actual or proposed, for completion of said actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding this matter please feel free to contact me at (937) 285-6107 or via email at Robert.Ostendorf@epa.state.oh.us.

Sincerely,



Bob Ostendorf Jr.
Division of Surface Water
Permit Section

Cc: Bob Gomez, Winelco, Inc.