



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 3, 2011

Mr. Robert Havrilla,
V.P. Property and Assets
Diamond Oaks Career Development Center
6375 Harrison Avenue
Cincinnati, Ohio 45247

Re: Hamilton County, Diamond Oaks Career Development Center, NPDES Permit Violations

Dear Mr. Havrilla:

The Ohio EPA has completed a compliance evaluation of the Data Monitoring Reports covering the months of July through December 2010 for Diamond Oaks Career Development Center. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0047287; OEPA Permit # 1PT00050*ED). The specific instances of noncompliance are as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2010	Ammonia	Monthly Conc	1.0	4.2	9/1/2010
September 2010	Ammonia	Weekly Conc	1.5	8.3	9/15/2010
October 2010	Ammonia	Monthly Conc	1.0	7.5	10/1/2010
October 2010	Ammonia	Weekly Conc	1.5	15	10/15/2010
December 2010	Ammonia	Monthly Conc	2.5	13	12/1/2010
December 2010	Ammonia	Weekly Conc	3.75	9.3	12/1/2010
December 2010	Ammonia	Weekly Conc	3.75	17.2	12/15/2010

Frequency / Monitoring Violations						
Reporting Period	Parameter	Sample Frequency	Expected	Reported	Violation Date	
July 2010	Temperature	1/Day	1	0	07/02/2010	
July 2010	Temperature	1/Day	1	0	07/14/2010	
July 2010	Temperature	1/Day	1	0	07/30/2010	
July 2010	Color	1/Day	1	0	07/02/2010	
July 2010	Color	1/Day	1	0	07/14/2010	
July 2010	Color	1/Day	1	0	07/30/2010	
July 2010	Odor	1/Day	1	0	07/02/2010	
July 2010	Odor	1/Day	1	0	07/14/2010	
July 2010	Odor	1/Day	1	0	07/30/2010	
July 2010	Turbidity	1/Day	1	0	07/02/2010	




Frequency / Monitoring Violations (Cont.)						
Reporting Period	Parameter	Sample Frequency	Expected	Reported	Violation Date	
July 2010	Turbidity	1/Day	1	0	07/14/2010	
July 2010	Turbidity	1/Day	1	0	07/30/2010	
July 2010	Flow Rate	1/Day	1	0	07/30/2010	
November 2010	Temperature	1/Day	1	0	11/26/2010	
November 2010	Color	1/Day	1	0	11/26/2010	
November 2010	Odor	1/Day	1	0	11/26/2010	
November 2010	Turbidity	1/Day	1	0	11/26/2010	
December 2010	Flow Rate	1/Day	1	0	12/31/2010	

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is required at this time. Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at Robert.Ostendorf@epa.state.oh.us.

Sincerely,



Bob Ostendorf Jr.
 Division of Surface Water
 Permit Section

