



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

November 21, 2007

Mr. James Brett  
Westland Development Limited Corporation  
5700 Dry Fork Road  
Cleves, Ohio 45002

**Re: Hamilton County, Dry Fork MHP, NPDES Permit Violations**

Dear Mr. Brett:

We have reviewed your Monthly Operating Reports (MORs) covering the months of July through September 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0109380; OEPA Permit # 1PY00001\*BD). The specific instances of noncompliance and deficiencies were as follows:

**Effluent Limit Violations**

Reporting Period	Parameter	Limit Type	Limit	Reported Value
July 2007	Fecal Coliform	7D Conc	2000	7800.
August 2007	Fecal Coliform	7D Conc	2000	4650.


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason(s) for the above referenced violation(s), as well as a description of the action(s) taken or proposed to prevent any further violation(s). Your response should include the dates, either actual or proposed, for completion of the action(s). Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

Mr. James Brett  
November 21, 2007  
Page 2

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,

  
Laura Pohlman  
Division of Surface Water  
Permit Section