



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

August 12, 2010

Mr. Bud Black
Eagles Lake Condominium Association
5150 Shoreview Run
Cincinnati, Ohio 45248

Re: Hamilton County, Eagles Lake Condominium Association, Notice of Violation

Dear Mr. Black:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of September 2009 through June 2010 for the Eagles Lake Condominium Association. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0093050; OEPA Permit # 1PW00029*DD). The specific instances of noncompliance are as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2009	Chlorine	Daily Conc	0.019	0.080	9/1/2009
September 2009	Chlorine	Daily Conc	0.019	0.150	9/2/2009
September 2009	Chlorine	Daily Conc	0.019	0.110	9/15/2009
September 2009	Chlorine	Daily Conc	0.019	0.100	9/16/2009
September 2009	DO	Daily Conc	5.0	4.0	9/16/2009
September 2009	Chlorine	Daily Conc	0.019	0.100	9/17/2009
September 2009	Chlorine	Daily Conc	0.019	0.090	9/18/2009
September 2009	Chlorine	Daily Conc	0.019	0.050	9/21/2009
September 2009	Chlorine	Daily Conc	0.019	0.050	9/23/2009
September 2009	Chlorine	Daily Conc	0.019	0.050	9/24/2009
September 2009	DO	Daily Conc	5.0	4.0	9/24/2009
September 2009	Chlorine	Daily Conc	0.019	0.050	9/28/2009
September 2009	Chlorine	Daily Conc	0.019	0.050	9/29/2009
October 2009	DO	Daily Conc	5.0	2.8	10/7/2009
October 2009	DO	Daily Conc	5.0	3.0	10/14/2009
October 2009	DO	Daily Conc	5.0	1.8	10/21/2009
October 2009	pH	Daily Conc	6.5	6.4	10/27/2009
October 2009	DO	Daily Conc	5.0	2.8	10/27/2009

Effluent Limit Violations (Cont.)					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
November 2009	DO	Daily Conc	5.0	4.0	11/4/2009
November 2009	DO	Daily Conc	5.0	3.6	11/11/2009
November 2009	DO	Daily Conc	5.0	3.2	11/18/2009
November 2009	DO	Daily Conc	5.0	4.6	11/24/2009
December 2009	DO	Daily Conc	5.0	4.0	12/3/2009
December 2009	DO	Daily Conc	5.0	4.0	12/9/2009
December 2009	DO	Daily Conc	5.0	4.6	12/16/2009
December 2009	DO	Daily Conc	5.0	3.6	12/23/2009
January 2010	DO	Daily Conc	5.0	4.6	1/13/2010
May 2010	DO	Daily Conc	5.0	2.0	5/18/2010

Frequency / Monitoring Violations						
Reporting Period	Parameter	Sample Frequency	Expected	Reported	Violation Date	
May 2010	Flow	Daily	1	0	05/01/2010	
May 2010	Flow	Daily	1	0	05/02/2010	
May 2010	Flow	Daily	1	0	05/03/2010	
May 2010	Flow	Daily	1	0	05/04/2010	
May 2010	Flow	Daily	1	0	05/05/2010	
May 2010	Flow	Daily	1	0	05/06/2010	
May 2010	Flow	Daily	1	0	05/07/2010	
May 2010	Flow	Daily	1	0	05/08/2010	
May 2010	Flow	Daily	1	0	05/09/2010	
May 2010	Flow	Daily	1	0	05/10/2010	
May 2010	Flow	Daily	1	0	05/11/2010	
May 2010	Flow	Daily	1	0	05/12/2010	
May 2010	Flow	Daily	1	0	05/13/2010	
May 2010	Flow	Daily	1	0	05/14/2010	
May 2010	Flow	Daily	1	0	05/15/2010	
May 2010	Flow	Daily	1	0	05/16/2010	
May 2010	Flow	Daily	1	0	05/17/2010	
May 2010	Flow	Daily	1	0	05/18/2010	
May 2010	Flow	Daily	1	0	05/19/2010	
May 2010	Flow	Daily	1	0	05/20/2010	
May 2010	Flow	Daily	1	0	05/21/2010	
May 2010	Flow	Daily	1	0	05/22/2010	

Frequency/Monitoring Violations (Cont.)						
Reporting Period	Parameter	Sample Frequency	Expected	Reported	Violation Date	
May 2010	Flow	Daily	1	0	05/23/2010	
May 2010	Flow	Daily	1	0	05/24/2010	
May 2010	Flow	Daily	1	0	05/25/2010	
May 2010	Flow	Daily	1	0	05/26/2010	
May 2010	Flow	Daily	1	0	05/27/2010	
May 2010	Flow	Daily	1	0	05/28/2010	
May 2010	Flow	Daily	1	0	05/29/2010	
May 2010	Flow	Daily	1	0	05/30/2010	
May 2010	Flow	Daily	1	0	05/31/2010	

Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations. The Ohio EPA has received a response for the chlorine violations which occurred in August and September of 2009. The Ohio EPA also received a response for the Dissolved Oxygen violations which occurred on November 11, 18 and December 3 of 2009. Your response to the balance of the violations listed above should include the dates, either actual or proposed, for completion of said actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding this matter please feel free to contact me at (937) 285-6107 or via email at Robert.Ostendorf@epa.state.oh.us.

Sincerely,



Bob Ostendorf Jr.
Division of Surface Water
Permit Section

Cc: Mr. Dennis Feichtner, National Wastewater Industries, Inc.

