



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

August 20, 2009

Jim Leslie
City of Harrison
10999 Campbell Road
Harrison, Ohio 45030

RE: Notice of Violation
NPDES Permit 1PC00002*ID

Dear Mr. Leslie:

We have received your self-monitoring report for the month of July, 2009, for the City of Harrison's Wastewater Treatment Plant. Our review indicates a violation of the conditions of the NPDES permit for the facility. The specific instance of noncompliance is as follows:

EFFLUENT LIMIT VIOLATIONS AT OUTFALL 001

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Oil and Grease	7/2/2009	10 mg/l	103 mg/l

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

I have reviewed your noncompliance notification that was received in this office on July 30, 2009. No further information is required at this time. If you have any questions about this Notice of Violation letter, please call me at (937) 285-6101.

Sincerely,

Mary Osika
Environmental Specialist
Division of Surface Water

