



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korfeski, Director

February 18, 2010

Jim Leslie
City of Harrison
10999 Campbell Road
Harrison, Ohio 45030

RE: Notice of Violation
Harrison WWTP
NPDES Permit 1PC00002*ID
Application No. OH0021440

Dear Mr. Leslie:

We have received your self monitoring report fro the month of January, 2010, for the City of Harrison's Wastewater Treatment Plant. Our review indicates violations of the conditions of the NPDES permit for the facility. The specific instances of noncompliance is as follows:

EFFLUENT LIMIT VIOLATIONS AT OUTFALL 001

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Nitrogen, Ammonia	week 1/1/2010	4.5 mg/l	4.7 mg/l
Nitrogen, Ammonia	week 1/8/2010	4.5 mg/l	13.2 mg/l
Nitrogen, Ammonia	Month 1/2010	3.0 mg/l	4.9 mg/l

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

I have reviewed your noncompliance notifications that were received in this office on January 14 and 21 of 2010. No further information is required at this time. If you have any

Jim Leslie, City of Harrison
February 18, 2010
Page 2

questions about this Notice of Violation letter, please call me at (937) 285-6101.

Sincerely,

A handwritten signature in cursive script, appearing to read "Mary Osika".

Mary Osika
Environmental Specialist
Division of Surface Water

cc: Bill Fischbein, Legal