



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

May 17, 2010

Jim Leslie  
City of Harrison  
10999 Campbell Road  
Harrison, Ohio 45030

RE: Notice of Violation  
Harrison WWTP  
NPDES Permit 1PC00002\*ID  
Application No. OH0021440

Dear Mr. Leslie:

We have received your self-monitoring report for the month of April, 2010, for the City of Harrison's Wastewater Treatment Plant. Our review indicates a violation of the conditions of the NPDES permit for the facility. The specific instance of noncompliance is as follows:

**EFFLUENT LIMIT VIOLATIONS AT OUTFALL 001**

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Total Suspended Solids	week 4/22/2010	18 mg/l	22.66 mg/l

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Jim Leslie, City of Harrison  
May 17, 2010  
Page 2

I have reviewed your noncompliance notification letter that was received in this office on May 4, 2010. No further information is required at this time. If you have any questions regarding this Notice of Violation letter, please call me at (937) 285-6101.

Sincerely,

A handwritten signature in cursive script, appearing to read "Mary Osika", written in black ink.

Mary Osika  
Environmental Specialist  
Division of Surface Water

cc: Bill Fischbein, Legal