



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 15, 2011

Jim Leslie  
City of Harrison WWTP  
10999 Campbell Road  
Harrison, Ohio 45030

RE: Notice of Violation  
Harrison WWTP  
NPDES Permit 1PC00002\*ID  
Application No. OH0021440

Dear Mr. Leslie:

We have received your self-monitoring report for the month of May 2011, for the City of Harrison's Wastewater Treatment Plant. Our review indicates violations of the conditions of the NPDES permit for the facility. The specific instances of noncompliance is as follows:

**EFFLUENT LIMIT VIOLATIONS AT OUTFALL 001**

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Ammonia – N	5/8/2011	1.5 mg/l	3.17 mg/l
Ammonia – N	May 2011	1.0 mg/l	1.08 mg/l

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

I have reviewed your noncompliance notification letter that was received in this office on May 31, 2011. No further information is required at this time. If you have any questions regarding this Notice of Violation letter, please call me at (937) 285-6101.

Sincerely,

Mary Osika  
Environmental Specialist  
Division of Surface Water

ec: Joel McGuire, City of Harrison

