



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 29, 2011

Joel McGuire, Mayor  
City of Harrison  
300 George Street  
Harrison, Ohio 45030

RE: Reconnaissance Inspection  
Notice of Violation  
NPDES Permit 1PC00002\*ID/OH0021440

Dear Mayor McGuire:


On August 17, 2011, I conducted a brief inspection at the Harrison Wastewater Treatment Plant. A copy of my inspection form is attached. Also attached is a Notice of Violation for recent permit limit exceedances experienced by the plant in July, 2011. No response is necessary. If you have any questions, please call me at (937) 285-6101.

Sincerely,

Mary Osika  
Environmental Specialist  
Division of Surface Water

Enclosure

cc: Jim Leslie/Bryan Warders, Operators of Record, Harrison






State of Ohio Environmental Protection Agency  
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PC00002*ID	OH0021440	8/17/2011	C	S	II

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
City of Harrison WWTP 10999 Campbell Road Harrison, Ohio	11:15 am	8/1/2011
	Exit Time	Permit Expiration Date
	11:35 am	1/31/2013
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Bob Haas, Operator	513-367-3725	
Name, Address and Title of Responsible Official	Phone Number	
Joel McGuire, Mayor City of Harrison 300 George Street Harrison, Ohio 45030	513-367-2111	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	N	Flow Measurement	N	Pretreatment
S	Records/Reports	N	Laboratory	S	Compliance Schedule
S	Operations & Maintenance	S	Effluent/Receiving Waters	S	Self-Monitoring Program
S	Facility Site Review	N	Sludge Storage/Disposal	S	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)	
<p>A brief inspection of the Harrison WWTP was conducted by Mary Osika and 4 college interns. Preliminary treatment, oxidation ditches, clarifiers, disinfection and final discharge were viewed. Nothing out of the ordinary was noted.</p> <p>Attached is a Notice of Violation for recent permit limit exceedances.</p>	
Inspector	Reviewer
 Date 8/29/2011	 Date 8/29/11
Mary Osika Division of Surface Water Southwest District Office	Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office

Permit # : 1PC00002\*ID  
NPDES # : OH0021440

**HARRISON WWTP 1PC00002\*ID**  
**NOTICE OF VIOLATION**

The review of the self-monitoring reports for the months of June and July, 2011, for the discharge 001 from the Harrison Wastewater Treatment Plant indicates effluent limit violations in regard to the NPDES permit 1PC00002\*ID for this facility. The specific instances of non-compliance are as follows:

**EFFLUENT LIMIT VIOLATION AT OUTFALL 001**

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Ammonia – N	7/22/2011	1.5 mg/l	6.48 mg/l
Ammonia – N	7/2011	1.0 mg/l	1.78 mg/l

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

A non-compliance notification was received on August 1, 2011 regarding the violations for July 2011. No further information is requested.