



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

June 29, 2007

Ms. Anna Drexler
Haven Park West MHP
5765 Ocala Court
Cincinnati, Ohio 45239

Re: Hamilton County, Haven Park West MHP, Self-monitoring Report Violations

Dear Ms. Drexler:

We have reviewed your Monthly Operating Reports (MORs) covering the months of December 2006 through May 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0105589; OEPA Permit # 1PV00086*AD and 1PV00086*BD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations

Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
February 2007	TSS	Monthly	mg/l	12	39
February 2007	TSS	Weekly	mg/l	18	39
February 2007	TSS	Monthly	kg/day	1.0	1.6
April 2007	DO	Daily	mg/l	6.0	3.2
May 2007	DO	Daily	mg/l	6.0	5.0
May 2007	DO	Daily	mg/l	6.0	4.1
May 2007	DO	Daily	mg/l	6.0	5.9

Please be advised that failure to comply with the effluent limitations or to satisfy the reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have received your report addressing the reason for the February 2007 violations and the actions being taken to prevent further occurrences. However, the April and May 2007 violations have not been addressed. Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the April and May 2007 violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Ms. Anna Drexler
June 29, 2007
Page 2

Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,

Laura R. Pohlman

~~Laura Pohlman~~

Division of Surface Water
Permit Section

cc: Mike Ullman, Winelco, Inc.