



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

November 30, 2010

Anna Drexler
Haven Park West Mobile Home Park
9179 New Haven Road
Harrison, Ohio 45030

RE: NOTICE OF VIOLATION
Haven Park West MHP
Hamilton County
NPDES Permit # 1PV00086*BD

Dear Ms. Drexler :

I have performed a compliance review under your NPDES permit for the review period of January 2009 through October 2010. My review shows that there were sampling violations for failure to take a sample for Total Suspended Solids, Nitrogen Ammonia and CBOD5 for the month of April 2010.

I have also reviewed your self-monitoring reports for the months of January 2009 through October 2010, for the discharge outfall 001 from the wastewater treatment system. The review indicates the following effluent limit violations of the NPDES permit for this facility.

EFFLUENT LIMIT VIOLATIONS AT OUTFALL 001

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
T. Suspended Solids	3/1/2009	1.0 kg/d	1.423 kg/d
CBOD5	3/1/2009	0.87 kg/d	0.872 kg/d
Dissolved Oxygen	3/2/2009	6.0 mg/l	4.5 mg/l
Dissolved Oxygen	3/9/2009	6.0 mg/l	5.0 mg/l
Dissolved Oxygen	4/13/2009	6.0 mg/l	2.5 mg/l
Dissolved Oxygen	4/27/2009	6.0 mg/l	3.6 mg/l
Nitrogen Ammonia	5/1/2009	1.0 mg/l	3.7 mg/l
Nitrogen Ammonia	5/1/2009	0.087 mg/l	0.504 mg/l
Nitrogen Ammonia	5/4/2009	1.5 mg/l	3.7 mg/l
Nitrogen Ammonia	5/4/2009	0.13 mg/l	0.504 mg/l
Dissolved Oxygen	5/4/2009	6.0 mg/l	4.3 mg/l
Dissolved Oxygen	6/1/2009	6.0 mg/l	4.9 mg/l
Dissolved Oxygen	6/8/2009	6.0 mg/l	3.0 mg/l
Dissolved Oxygen	7/6/2009	6.0 mg/l	4.0 mg/l



EFFLUENT LIMIT VIOLATIONS AT OUTFALL 001

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Dissolved Oxygen	7/13/2009	6.0 mg/l	3.1 mg/l
Dissolved Oxygen	7/20/2009	6.0 mg/l	5.6 mg/l
Dissolved Oxygen	7/27/2009	6.0 mg/l	5.0 mg/l
Nitrogen Ammonia	8/1/2009	1.0 mg/l	3.0 mg/l
Nitrogen Ammonia	8/1/2009	0.087 mg/l	0.408 mg/l
Nitrogen Ammonia	8/3/2009	1.5 mg/l	3.0 mg/l
Nitrogen Ammonia	8/3/2009	0.13 mg/l	0.408 mg/l
Dissolved Oxygen	8/3/2009	6.0 mg/l	3.2 mg/l
Dissolved Oxygen	8/10/2009	6.0 mg/l	4.4 mg/l
Dissolved Oxygen	8/17/2009	6.0 mg/l	5.8 mg/l
Dissolved Oxygen	8/24/2009	6.0 mg/l	5.1 mg/l
Fecal Coliform	6/1/2010	1,000 c/100ml	1,200 c/100 ml
Fecal Coliform	6/15/2010	2,000 c/100ml	7,200 c/100 ml
Nitrogen Ammonia	9/1/2010	1.0 mg/l	2.5 mg/l
Nitrogen Ammonia	9/1/2010	0.087 mg/l	0.265 mg/l
Dissolved Oxygen	9/7/2010	6.0 mg/l	5.6 mg/l
Nitrogen Ammonia	9/7/2010	1.5 mg/l	2.5 mg/l
Nitrogen Ammonia	9/7/2010	0.13 mg/l	0.265 mg/l

Our office received non-compliance notifications from Winelco for these effluent limit violations. The main causes of the violations related to sand filter maintenance.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. No response is required for this Notice of Violation.

If you have any questions regarding this letter, please contact me at (937) 285-6101 or at my email address mary.osika@epa.state.oh.us.

Sincerely,



Mary Osika
Environmental Specialist
Division of Surface Water

ec: Eric Gibson - Winelco, Inc. & Greg Cassiere, Hamilton County Public Health

