



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

September 21, 2009

Mark Kreimer
P.O.Box 111
Miamitown, Ohio 45041

RE: NOTICE OF VIOLATION
Kreimer's Bierhaus
6052 State Route 128
NPDES Permit # 1PZ00064*BD

Dear Mr. Kreimer:

I have reviewed your self-monitoring reports for the months of February, March and April, 2009, for the discharge outfall 001 from the wastewater treatment system. The review indicates monitoring violations contained in the NPDES permit for this facility. The specific instances of noncompliance are as follows:

MONITORING/REPORTING VIOLATION AT OUTFALL 001

<u>Parameter</u>	<u>Date</u>	<u>Meas. Freq.</u>	<u>Expected</u>	<u>Reported</u>
Flow Rate	February 2009	1/month	1	0
Flow Rate	March 2009	1/month	1	0
Ammonia-N	March 2009	1/quarter	1	0
CBOD5	March 2009	1/quarter	1	0
T. Susp. Solids	March 2009	1/quarter	1	0
pH	March 2009	1/quarter	1	0
Oil & Grease	March 2009	1/quarter	1	0
Diss. Oxygen	March 2009	1/quarter	1	0
Flow Rate	April 2009	1/month	1	0

The NPDES permit also requires sludge removed to be reported under the 588 station on the self-monitoring report forms. Reports for the 588 station have not been submitted for the past six months. Our office has not received self-monitoring reports for May, June, and July 2009 for monitoring station 001 as well. This is a violation of the NPDES permit under Part III, 4. Reporting.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement

Mark Kreimer
September 21, 2009
Page 2

action pursuant to the Ohio Revised Code Chapter 6111. You are required to respond to this letter within 10 days of receipt of this letter. Your response should indicate what caused the non-compliance and the actions you will take to comply with the requirements of the NPDES permit.

If you have any questions regarding this letter, please contact at (937) 285-6101 or by email at mary.osika@epa.state.oh.us.

Sincerely,



☐ Mary Osika
Environmental Specialist
Division of Surface Water

cc: Greg Ross, Winelco