



Environmental
Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PV0011620101203

HAMILTON NEW HORIZONS MHP - FLORA

OSIKA, MARY 2010/12/03



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

December 3, 2010

Mandy Cordes
New Horizons Mobile Home Park
11007 Flora Road
Harrison, Ohio 45030

RE: NOTICE OF VIOLATION
New Horizons MHP - Flora
Hamilton County
NPDES Permit # 1PV00116*BD

Dear Ms. Cordes :

I have performed a compliance review under your NPDES permit for the review period of January 2009 through October 2010. My review shows that there were some reporting violations for failure to take color, odor, turbidity and temperature readings in July, August and September 2010.

I have also reviewed your self-monitoring reports for the months of January 2009 through October 2010, for the discharge outfall 001 from the wastewater treatment system. The review indicates the following effluent limit violations of the NPDES permit for this facility.

EFFLUENT LIMIT VIOLATIONS AT OUTFALL 001

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Dissolved Oxygen	7/6/2009	6.0 mg/l	4.5 mg/l
Total Suspended Solids	11/1/2009	12 mg/l	25 mg/l
Total Suspended Solids	11/9/2009	18 mg/l	25 mg/l
Fecal Coliform	6/1/2010	1,000 c/100 ml	1,200 c/100 ml
Fecal Coliform	6/8/2010	2,000 c/100 ml	7,200 c/100 ml

Our office received non-compliance notifications from Winelco for these effluent limit violations and reporting violations. No response is required for this Notice of Violation.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.



Mandy Cordes
December 3, 2010
Page 2

If you have any questions regarding this letter, please contact me at (937) 285-6101 or at my email address mary.osika@epa.state.oh.us.

Sincerely,

A handwritten signature in cursive script, appearing to read "Mary Osika".

Mary Osika
Environmental Specialist
Division of Surface Water

ec: Eric Gibson - Winelco, Inc. & Greg Cassiere, Hamilton County Public Health

