



Environmental
Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PW0003220090924

HAMILTON NORTHCREST APARTMENTS

OSTENDORF, ROBE 2009/09/24



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 24, 2009

Ms. Kathleen Klug
Northcrest Apartments
5422-C Bluesky Drive
Cincinnati, Ohio 45247

Re: Hamilton County, Northcrest Apartments, NPDES Permit Violations

Dear Ms. Klug:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of July 2009 through August 2009 for Northcrest Apartments. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0115797; OEPA Permit # 1PW00032*BD). The specific instances of noncompliance are as follows:


Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
July 2009	Chlorine	Daily Conc	0.019	0.06	7/1/2009
July 2009	Chlorine	Daily Conc	0.019	0.06	7/2/2009
July 2009	Chlorine	Daily Conc	0.019	0.05	7/3/2009
July 2009	Chlorine	Daily Conc	0.019	0.05	7/6/2009
July 2009	Chlorine	Daily Conc	0.019	0.06	7/7/2009
July 2009	Chlorine	Daily Conc	0.019	0.05	7/8/2009
July 2009	Chlorine	Daily Conc	0.019	0.06	7/9/2009
July 2009	Chlorine	Daily Conc	0.019	0.06	7/13/2009
July 2009	Chlorine	Daily Conc	0.019	0.06	7/14/2009
July 2009	Chlorine	Daily Conc	0.019	0.05	7/15/2009
July 2009	DO	Daily Conc	6.0	3.0	7/15/2009
July 2009	Chlorine	Daily Conc	0.019	0.06	7/16/2009
July 2009	Chlorine	Daily Conc	0.019	0.08	7/20/2009
July 2009	Chlorine	Daily Conc	0.019	0.1	7/21/2009
July 2009	Chlorine	Daily Conc	0.019	0.07	7/22/2009
July 2009	pH	Daily Conc	6.5	6.4	7/22/2009
July 2009	Chlorine	Daily Conc	0.019	0.08	7/23/2009
July 2009	Chlorine	Daily Conc	0.019	0.07	7/24/2009

Effluent Limit Violations (Cont.)					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
July 2009	Chlorine	Daily Conc	0.019	0.1	7/27/2009
July 2009	Chlorine	Daily Conc	0.019	0.06	7/30/2009
July 2009	Chlorine	Daily Conc	0.019	0.08	7/31/2009
August 2009	Chlorine	Daily Conc	0.019	0.06	8/3/2009
August 2009	Chlorine	Daily Conc	0.019	0.08	8/4/2009
August 2009	Chlorine	Daily Conc	0.019	0.07	8/5/2009
August 2009	Chlorine	Daily Conc	0.019	0.06	8/6/2009
August 2009	Chlorine	Daily Conc	0.019	0.07	8/7/2009
August 2009	Chlorine	Daily Conc	0.019	0.08	8/10/2009
August 2009	Chlorine	Daily Conc	0.019	0.09	8/11/2009
August 2009	Chlorine	Daily Conc	0.019	0.06	8/13/2009
August 2009	Chlorine	Daily Conc	0.019	0.07	8/14/2009
August 2009	Chlorine	Daily Conc	0.019	0.07	8/17/2009
August 2009	Chlorine	Daily Conc	0.019	0.11	8/18/2009
August 2009	Chlorine	Daily Conc	0.019	0.05	8/19/2009
August 2009	Chlorine	Daily Conc	0.019	0.05	8/26/2009
August 2009	Chlorine	Daily Conc	0.019	0.09	8/28/2009
August 2009	Chlorine	Daily Conc	0.019	0.11	8/31/2009

The Ohio EPA has received a response regarding the above referenced Chlorine violations and no further response is required at this time. Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the balance of the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations. Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at Robert.Ostendorf@epa.state.oh.us.

Sincerely,



Bob Ostendorf Jr.
Division of Surface Water
Permit Section

Cc: Mr. Dennis Feichtner, National Wastewater Industries