



**Environmental  
Protection Agency**

**Ted Strickland.** Governor  
**Lee Fisher.** Lt. Governor  
**Chris Korleski.** Director



\*1IG0000320071203\*

HAMILTON PETER CREMER NORTH AMERICA LP

POHLMAN, LAURA 2007/12/03



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 3, 2007

Mr. Raymond Bitzer  
Peter Cremer North America  
3117 Southside Avenue  
Cincinnati, Ohio 45204

**Re: Hamilton County, Peter Cremer North America, NPDES Permit Violations**

Dear Mr. Bitzer:

We have reviewed your Monthly Operating Reports (MORs) covering the months of July through September 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0010120; OEPA Permit # 1IG00003\*GD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations for Outfall 001				
Reporting Period	Parameter	Limit Type	Limit	Reported Value
July 2007	Oil and Grease, Total	30D Conc	15	24
July 2007	Oil and Grease, Total	1D Conc	20	24
August 2007	Oil and Grease, Total	30D Conc	15	40
August 2007	Oil and Grease, Total	1D Conc	20	40
September 2007	Oil and Grease, Total	30D Conc	15	26
September 2007	Oil and Grease, Total	1D Conc	20	26
September 2007	pH	1D Conc	6.5	5.7

**Numerous monitoring violations-** Numerous monitoring violations were noted for the Biochemical Oxygen Demand, Total Precipitation, Chemical Oxygen Demand, TSS, and flow rate. This parameter must be monitored and reported on a daily basis.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or



Mr. Raymond Bitzer  
December 3, 2007  
Page 2

proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

A handwritten signature in cursive script that reads "Laura Pohlman".

Laura Pohlman  
Division of Surface Water  
Permit Section

CC: Mike Doll, PCNA

