



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director



\*1PV0009620071129\*

HAMILTON RIVERVIEW CROSSING WWTP

POHLMAN, LAURA 2007/11/29



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

November 29, 2007

Mr. Don Frazier  
Holiday Homes, Inc.  
1252 Goshen Road  
Milford, Ohio 45150

**Re: Hamilton County, Riverview Crossing MHP WWTP, NPDES Permit Violations**

Dear Mr. Frazier:

We have reviewed your Monthly Operating Reports (MORs) covering the months of July through September 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0118974; OEPA Permit # 1PV00096\*BD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations for Outfall 001				
Reporting Period	Parameter	Limit Type	Limit	Reported Value
August 2007	pH	1D Conc	6.5	6.3
August 2007	pH	1D Conc	6.5	6.4
August 2007	pH	1D Conc	6.5	6.4
August 2007	pH	1D Conc	6.5	6.3
September 2007	pH	1D Conc	6.5	6.3
September 2007	pH	1D Conc	6.5	6.2
September 2007	pH	1D Conc	6.5	6.4
September 2007	pH	1D Conc	6.5	6.4
September 2007	pH	1D Conc	6.5	6.3
September 2007	pH	1D Conc	6.5	6.4

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either



1-17


.

Mr. Don Frazier  
November 29, 2007  
Page 2

actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,

A handwritten signature in cursive script that reads "Laura Pohlman".

Laura Pohlman  
Division of Surface Water  
Permit Section

