



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PT0004720110411

HAMILTON SAINT JOHN THE BAPTIST CHURCH AND SCH SARLE, EDWARD 2011/04/11



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Sevago

April 11, 2011

Ms. Donna Sunderhaus
St. John the Baptist Church and School
5361 Dry Ridge Road
Cincinnati, Ohio 45252

Re: Hamilton County, St. John the Baptist Church and School
NPDES Permit Violations

Dear Ms. Sunderhaus:

We have reviewed your Discharge Monitoring Reports (DMRs) covering the months of November 2010 through February 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0046973; OEPA Permit # 1PT00047*AD). The specific instances of noncompliance were as follows:

Effluent Violations for November 2010 through February 2011					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
November 2010	Ammonia	Monthly	mg/l	3.0	8.9
November 2010	TSS	Monthly	mg/l	12	45
November 2010	Ammonia	Weekly	mg/l	4.5	8.9
November 2010	TSS	Weekly	mg/l	18	45
December 2010	TSS	Monthly	mg/l	12	73
December 2010	TSS	Weekly	mg/l	18	73
January 2011	TSS	Monthly	mg/l	12	42
January 2011	TSS	Weekly	mg/l	18	42
February 2011	TSS	Monthly	mg/l	12	34
February 2011	TSS	Weekly	mg/l	18	34

Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have received your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Your explanation is not satisfactory and we request, within ten days of receipt of this letter, written information as to what additional steps you take to prevent further occurrences. Please indicate the status of

Ms. Donna Sunderhaus
April 11, 2011
Page 2

constructing your sewer extension. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

A handwritten signature in cursive script, appearing to read "Ned Sarle".

Ned Sarle
Division of Surface Water
Permit Section

cc: Eric Gibson, Winelco, Inc.