



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1PR0010220071127

HAMILTON VINOKLET WINERY

POHLMAN, LAURA 2007/11/27

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 27, 2007

Mr. Kreso Mikulic
Vinoklet Winery
11069 Colerain Avenue
Cincinnati, Ohio 45252

Re: Hamilton County, Vinoklet Winery, NPDES Permit Violations

Dear Mr. Mikulic:

We have reviewed your Monthly Operating Reports (MORs) covering the months of July through September 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0127141; OEPA Permit # 1PR00102*AD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations for Outfall 001				
Reporting Period	Parameter	Limit Type	Limit	Reported Value
July 2007	pH	1D Conc	9.0	9.5
July 2007	pH	1D Conc	9.0	9.8
August 2007	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.6
August 2007	Nitrogen, Ammonia (NH3)	7D Conc	1.5	1.6
September 2007	Nitrogen, Ammonia (NH3)	30D Conc	1.0	16.3
September 2007	Nitrogen, Ammonia (NH3)	30D Qty	0.010	.017
September 2007	pH	1D Conc	9.0	9.8
September 2007	Nitrogen, Ammonia (NH3)	7D Conc	1.5	16.3
September 2007	Nitrogen, Ammonia (NH3)	7D Qty	0.015	.017
September 2007	pH	1D Conc	9.0	9.4

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either



Mr. Kreso Mikulic
November 27, 2007
Page 2

actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,

A handwritten signature in cursive script that reads "Laura Pohlman".

Laura Pohlman
Division of Surface Water
Permit Section