



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1PW0003120090924

HAMILTON WESSELMAN WOODS WWTP

OSTENDORF, ROBE 2009/09/24

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 24, 2009

Mr. Donald G. Linn P.E.
Superintendent
Wesselman Treatment Plant
1600 Gest Street
Cincinnati, Ohio 45204

Re: Hamilton County, Wesselman Treatment Plant, NPDES Permit Violations

Dear Mr. Linn:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of January 2009 through ~~September~~ ^{August} 2009 for the Wesselman Treatment Plant. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0112887; OEPA Permit # 1PW00031*DD). The specific instances of noncompliance are as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2009	TSS	Monthly Conc	12	15	1/1/2009
January 2009	TSS	Monthly Qty	1.36	2.02	1/1/2009
January 2009	TSS	Weekly Conc	18	34	1/22/2009
January 2009	TSS	Weekly Qty	2.04	4.12	1/22/2009
February 2009	Ammonia	Monthly Conc	2	8	2/1/2009
February 2009	Ammonia	Monthly Qty	0.22	1.6	2/1/2009
February 2009	Ammonia	Weekly Conc	3	16.9	2/22/2009
February 2009	Ammonia	Weekly Qty	0.34	3.1	2/22/2009
May 2009	TSS	Weekly Qty	2.04	2.07	5/22/2009
June 2009	Ammonia	Monthly Qty	0.22	0.23	6/1/2009


Our records indicate that a response for the above referenced violations has been received and an additional response is not required at this time. Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES

Mr. Donald G. Linn P.E.
September 24, 2009
Page 2

Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at Robert.Ostendorf@epa.state.oh.us.

Sincerely,

A handwritten signature in cursive script that reads "Bob Ostendorf Jr." with a stylized flourish at the end.

Bob Ostendorf Jr.
Division of Surface Water
Permit Section