



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049



\*1PV0002320080128\*

HAMILTON WESTBROOK VILLAGE MHP

SARLE, EDWARD ; 2008/01/28

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 28, 2008

Mr. Lanny Holbrook, President  
1400 Fourth and Race Tower  
105 West Fourth Street  
Cincinnati, Ohio 45202

Re: Hamilton County, Westbrook Village MHP, NPDES Permit Violations

Dear Mr. Holbrook:

We have reviewed your Monthly Operating Reports (MORs) covering the months of November and December 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0049930; OEPA Permit # 1PV00023\*ED). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Limit	Reported Value
November 2007	Ammonia	Monthly	mg/l	2	4.9
November 2007	Ammonia	Weekly	mg/l	3	9.7

Effluent Monitoring Violations						
Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
November 2007	001	Temperature	1/Day	1	0	11/14/2007
November 2007	001	DO	1/Day	1	0	11/23/2007
November 2007	001	Temperature	1/Day	1	0	11/23/2007
November 2007	001	pH	1/Day	1	0	11/23/2007
December 2007	001	pH	1/Day	1	0	12/18/2007
December 2007	001	Temperature	1/Day	1	0	12/18/2007
December 2007	001	DO	1/Day	1	0	12/18/2007
December 2007	001	Temperature	1/Day	1	0	12/26/2007
December 2007	001	DO	1/Day	1	0	12/26/2007
December 2007	001	pH	1/Day	1	0	12/26/2007




Mr. Lanny Holbrook  
January 28, 2008  
Page 2

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



Ned Sarle  
Division of Surface Water  
Permit Section

cc: Bob Reckers, Winelco, Inc.

