



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1PV0002320080910

HAMILTON WESTBROOK VILLAGE MHP

SARLE, EDWARD

2008/09/10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Savage



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 10, 2008

Mr. Lanny Holbrook, President
1400 Fourth and Race Tower
105 West Fourth Street
Cincinnati, Ohio 45202

Re: Hamilton County, Westbrook Village MHP, NPDES Permit Violations

Dear Mr. Holbrook:

We have reviewed your Monthly Operating Reports (MORs) covering the months of April through July 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0049930; OEPA Permit # 1PV00023*ED). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations for April through July 2008					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
April 2008	DO	Daily	mg/l	5.0	4.1
May 2008	Chlorine	Daily	mg/l	0.038	0.05
May 2008	Chlorine	Daily	mg/l	0.038	0.07
May 2008	Chlorine	Daily	mg/l	0.038	0.4
May 2008	Chlorine	Daily	mg/l	0.038	0.06
May 2008	Chlorine	Daily	mg/l	0.038	0.09
May 2008	Chlorine	Daily	mg/l	0.038	0.1
May 2008	Chlorine	Daily	mg/l	0.038	0.11
May 2008	Chlorine	Daily	mg/l	0.038	0.11
May 2008	Chlorine	Daily	mg/l	0.038	0.1
May 2008	Chlorine	Daily	mg/l	0.038	0.09
May 2008	Chlorine	Daily	mg/l	0.038	0.07
May 2008	Chlorine	Daily	mg/l	0.038	0.08
May 2008	Chlorine	Daily	mg/l	0.038	0.1
May 2008	Chlorine	Daily	mg/l	0.038	0.12
May 2008	Chlorine	Daily	mg/l	0.038	0.1
June 2008	DO	Daily	mg/l	5.0	3.5
June 2008	Chlorine	Daily	mg/l	0.038	0.06

Mr. Lanny Holbrook
September 10, 2008
Page 2

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



Ned Sarle
Division of Surface Water
Permit Section

cc: Bob Reckers, Winelco, Inc.


Mr. Lanny Holbrook
September 10, 2008
Page 2

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



Ned Sarle
Division of Surface Water
Permit Section

cc: Bob Reckers, Winelco, Inc.

