



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1PV0002320110315

HAMILTON WESTBROOK VILLAGE MHP

OSIKA, MARY

2011/03/15

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

March 15, 2011

Mr. Lanny Holbrook, President
Heritage Management Group, Inc.
1400 Fourth and Race Tower
105 West Fourth Street
Cincinnati, Ohio 45202

RE: Westbrook Village Mobile Home Park
Notice of Violation
NPDES Permit 1PV00023*ED, OH0049930

Dear Mr. Holbrook:

Regarding the Westbrook Village Mobile Home Park's wastewater treatment plant, discharge monitoring reports have not been received by this agency for the months of August, September, October, November, December 2010 and January 2011. Failure to report the monitoring data as required by your NPDES permit is considered a violation of that permit.

Ohio EPA has also reviewed the discharge monitoring report for June 2010 that was recently submitted. The review showed one violation of the permit limits for the discharge from the wastewater treatment plant. The specific instance of noncompliance is as follows:

EFFLUENT LIMIT VIOLATION AT OUTFALL 001

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Chlorine, residual	5/10/2010	0.038 mg/l	0.05 mg/l

Please be advised that Ohio EPA has recommended legal enforcement action due to violations of the NPDES permit and Ohio Revised Code Chapter 6111. Each violation may incur penalties under Ohio Revised Code Chapter 6111.

You are required to respond to this notice of violation within 5 days of receipt of this letter discussing the submittal of discharge monitoring reports for this facility. You are also requested to discuss the effluent limit violation, cause of the violation and actions you are taking to prevent the reoccurrence.

Lanny Holbrook
March 15, 2011
Page 2

If you have any questions about this letter, please contact me at (937) 285-6101.

Sincerely,

A handwritten signature in cursive script, appearing to read "Mary Osika".

Mary Osika
Environmental Specialist
Division of Surface Water

cc: Kerrie Mosbacker, Westbrook Village MHP
Bob Reckers, Winelco
Greg Cassiere, Hamilton County Public Health

Lanny Holbrook
March 15, 2011
Page 2

If you have any questions about this letter, please contact me at (937) 285-6101.

Sincerely,

A handwritten signature in cursive script, appearing to read "Mary Osika".

Mary Osika
Environmental Specialist
Division of Surface Water

cc: Kerrie Mosbacher, Westbrook Village MHP
Bob Reckers, Winelco
Greg Cassiere, Hamilton County Public Health

