



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049



\*1PS0001120071127\*

HAMILTON WULLENWEBER MOTORS INC

POHLMAN, LAURA 2007/11/27

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

Ohio EPA is an Equal Opportunity Employer



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

November 27, 2007

Mr. Stuart Wullenweber  
Wullenweber Motors, Incorporated  
6315 Harrison Avenue  
Cincinnati, Ohio 45247

**Re: Hamilton County, Wullenweber Motors Inc, NPDES Permit Violations**

Dear Mr. Wullenweber:

We have reviewed your Monthly Operating Reports (MORs) covering the months of July through September 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0108979; OEPA Permit # 1PS00011\*CD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations for Outfall 001				
Reporting Period	Parameter	Limit Type	Limit	Reported Value
July 2007	Chlorine, Total	1D Conc	0.019	.25
July 2007	Chlorine, Total	1D Conc	0.019	.43
August 2007	Chlorine, Total	1D Conc	0.019	.65
August 2007	Chlorine, Total	1D Conc	0.019	.83
September 2007	Chlorine, Total	1D Conc	0.019	.64
September 2007	Chlorine, Total	1D Conc	0.019	.47

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."



Mr. Stuart Wullenweber  
November 27, 2007  
Page 2

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,

A handwritten signature in cursive script that reads "Laura Pohlman". The signature is written in black ink and is positioned to the left of the typed name.

Laura Pohlman  
Division of Surface Water  
Permit Section