



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049



\*1PB0010620090126\*

HIGHLAND LEESBURG WWTP

JACKSON, JOSHUA | 2009/01/26



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.  
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 26, 2009

Mayor & Council  
Village of Leesburg  
57 South Fairfield Street, P.O. Box 305  
Leesburg, OH 45135

Re: **Notice of Violation**  
**Village of Leesburg Wastewater Treatment Works / 1PB00106\*FD**

Ladies & Gentlemen:

We have reviewed your self-monitoring reports covering the months of July 2008 through November 2008, for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit. The specific instances of noncompliance were as follows:

**EFFLUENT LIMIT VIOLATIONS**  
**(Period of Review: July 2008 – November 2008)**

7D = Weekly 30D = Monthly 1D = Daily Conc. = Concentration (mg/l) Qty. = Quantity (Kg/Day)

| Reporting Period | Parameter                 | Limit Type | Limit | Reported Value |
|------------------|---------------------------|------------|-------|----------------|
| August 2008      | Copper, Total Recoverable | 30D Conc   | 22    | 141.           |
| August 2008      | Copper, Total Recoverable | 30D Qty    | 0.033 | .07578         |
| August 2008      | Copper, Total Recoverable | 1D Conc    | 35    | 141.           |
| August 2008      | Copper, Total Recoverable | 1D Qty     | 0.053 | .07578         |
| November 2008    | Copper, Total Recoverable | 30D Conc   | 22    | 48.            |
| November 2008    | Copper, Total Recoverable | 30D Qty    | 0.033 | .03615         |
| November 2008    | Copper, Total Recoverable | 1D Conc    | 35    | 48.            |

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at [Joshua.Jackson@epa.state.oh.us](mailto:Joshua.Jackson@epa.state.oh.us).

Respectfully,

A handwritten signature in black ink, appearing to read 'J. Jackson', written in a cursive style.

Joshua Jackson  
Environmental Specialist II  
Division of Surface Water

cc: Steven Canter, EES