



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049



\*1PB0010620070813\*

HIGHLAND LEESBURG WWTP

BARTOSZEK, JOSE 2007/08/13

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 14, 2007

Highland County  
Village of Leesburg WWTP  
57 South Fairfield Street  
Leesburg, Ohio 45135

**Re: Butler County, Entity, NPDES Permit Violations**

Dear Ladies and Gentlemen:

We have reviewed your Monthly Operating Reports (MORs) covering the months of January 2007 through June 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit. The specific instances of noncompliance and/or deficiencies were as follows:

Effluent Limit Violations For Outfall 001				
Reporting Period	Parameter	Limit Type	Limit	Reported Value
January 2007	CBOD 5 day	7D Qty	9.1	18.1
April 2007	Total Suspended Solids	30D Conc	12	19.1
April 2007	Total Suspended Solids	30D Qty	7.3	12.9
April 2007	Nitrogen, Ammonia (NH3)	30D Conc	4.0	7.7
April 2007	Nitrogen, Ammonia (NH3)	30D Qty	2.4	5.3
April 2007	CBOD 5 day	30D Conc	10	18.5
April 2007	CBOD 5 day	7D Conc	15	16.5
April 2007	CBOD 5 day	30D Qty	6.1	12.6
April 2007	CBOD 5 day	7D Qty	9.1	10.4
April 2007	Nitrogen, Ammonia (NH3)	7D Conc	6.0	8.05
April 2007	Nitrogen, Ammonia (NH3)	7D Qty	3.6	5.2
April 2007	Nitrogen, Ammonia (NH3)	7D Conc	6.0	8.3
April 2007	Nitrogen, Ammonia (NH3)	7D Qty	3.6	6.2
April 2007	CBOD 5 day	7D Conc	15	27
April 2007	CBOD 5 day	7D Qty	9.1	19.2
April 2007	Total Suspended Solids	7D Conc	18	36
April 2007	Total Suspended Solids	7D Qty	11	25.7
April 2007	Nitrogen, Ammonia (NH3)	7D Conc	6.0	10.4



Effluent Limit Violations For Outfall 001-cont.				
Reporting Period	Parameter	Limit Type	Limit	Reported Value
April 2007	Nitrogen, Ammonia (NH3)	7D Qty	3.6	7.4
April 2007	CBOD 5 day	7D Conc	15	18
April 2007	CBOD 5 day	7D Qty	9.1	12.8
May 2007	Nitrogen, Ammonia (NH3)	30D Conc	1.5	1.8
May 2007	Nitrogen, Ammonia (NH3)	7D Conc	2.3	3.4
May 2007	Nitrogen, Ammonia (NH3)	30D Qty	0.91	1.3
May 2007	Nitrogen, Ammonia (NH3)	7D Qty	1.4	2.6
May 2007	Nitrogen, Ammonia (NH3)	7D Conc	2.3	3.3
May 2007	Nitrogen, Ammonia (NH3)	7D Qty	1.4	1.8

Frequency Violations For Outfall 001				
Reporting Period	Parameter	Sample Frequency	Expected	Reported
January 2007	Nitrogen, Ammonia (NH3)	2/Week	2	1
January 2007	CBOD 5 day	2/Week	2	1
February 2007	Total Suspended Solids	2/Week	2	1
February 2007	CBOD 5 day	2/Week	2	1
February 2007	Total Suspended Solids	2/Week	2	1
February 2007	Nitrogen, Ammonia (NH3)	2/Week	2	1
February 2007	Nitrogen, Ammonia (NH3)	2/Week	2	1
February 2007	CBOD 5 day	2/Week	2	1
March 2007	Total Suspended Solids	2/Week	2	1
March 2007	Nitrogen, Ammonia (NH3)	2/Week	2	1
March 2007	CBOD 5 day	2/Week	2	1

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports for April 2007 addressing the reasons for the above effluent limits violations and the actions being taken to prevent further occurrences. However, please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the other above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include

Village of Leesburg  
August 14, 2007  
Page 3

the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,

A handwritten signature in black ink that reads "Laura R Pohlman". The signature is written in a cursive style with a large initial "L".

Laura Pohlman  
Division of Surface Water  
Permit Section

cc: Rick Ludwick, Wastewater Superintendent

