



**Environmental  
Protection Agency**

**Ted Strickland**, Governor  
**Lee Fisher**, Lt. Governor  
**Chris Korleski**, Director



\*1PD0002420100707\*

BROWN

FAYETTEVILLE PERRY TWP WWTP

JACKSON, JOSHUA 2010/07/07

**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Zarbeski, Director

July 7, 2010

Fayetteville Perry Township Sewer District  
Attn: Mr. Joseph Pierre  
P.O. Box 294  
Fayetteville, OH 45118

**RE: Notice of Violation  
Fayetteville Perry Township Wastewater Treatment Works  
NPDES Permit No. OH0119041/OEPA PERMIT NO. 1PD00024\*CD**

Dear Mr. Pierre:

We have reviewed your self-monitoring reports covering the months of January 2010, through May 2010, for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit. The specific instances of noncompliance were as follows:

**EFFLUENT LIMIT VIOLATIONS  
(Period of Review: January 2010 – December 2010)**

7D = Weekly    30D = Monthly    1D = Daily    Conc. = Concentration (mg/l)    Qty. = Quantity (Kg/Day)

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value
January 2010	603	pH	1D Conc	6.0	5.
January 2010	603	pH	1D Conc	9.0	11.4
February 2010	603	Fecal Coliform	1D Conc	1000	1346.
February 2010	603	Fecal Coliform	1D Conc	1000	3900.
March 2010	603	Fecal Coliform	1D Conc	1000	1680.
May 2010	603	Fecal Coliform	1D Conc	1000	1250.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.


Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must

Fayetteville-Perry Township Sewer District  
Page 2 of 2

be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at [Joshua.Jackson@epa.state.oh.us](mailto:Joshua.Jackson@epa.state.oh.us).

Respectfully,



Joshua Jackson  
Environmental Specialist II  
Division of Surface Water

Cc: Steve Canter, Environmental Engineering Services