



**Environmental  
Protection Agency**

**Ted Strickland**, Governor  
**Lee Fisher**, Lt. Governor  
**Chris Korteski**, Director



\*1PB0010120110629\*

BROWN

GEORGETOWN WWTP

JACKSON, JOSHUA 2011/06/29



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Georgetown Group

June 29, 2011

Mayor & Council  
Village of Georgetown  
301 S. Main Street  
Georgetown, OH 45121

**RE: Village of Georgetown WWTW/Compliance Evaluation Inspection  
NPDES Permit No. OH0021300/OEPA PERMIT NO. 1PB00101\*ID**

Ladies & Gentlemen:

On June 15, 2011, I conducted a NPDES Compliance Evaluation Inspection at the Village of Georgetown wastewater treatment works (WWTW). Derek Copas (WWTW Operator of Record) and John Teeters (WWTW operator) were present during this inspection. The purpose of the inspection was to evaluate compliance with the terms and conditions of the NPDES Permit. A copy of the report is provided within.

As noted in the report, there several deficient areas that need addressed without delay. **Please pay special attention to the "items requiring correction" shown in bold type; for there are compliance schedules associated with these items. Notification when each item has been completed shall be sent to the Ohio EPA Southwest District Office.**

Thank you for your time extended during the inspection process. If you have any questions, please feel free to contact me by phone at (937) 285-6029 or by e-mail at [joshua.jackson@epa.state.oh.us](mailto:joshua.jackson@epa.state.oh.us).

Respectfully,

Joshua Jackson  
Environmental Specialist II  
Division of Surface Water

Cc: Derek Copas, Village of Georgetown (w/report)  
Gary Williams, Jones & Henry Engineers (w/report)  
S. Kelly Jones, Village of Georgetown (w/report)  
Jim Hext, Rumpke Waste, Inc. (w/report)

Enclosures



State of Ohio Environmental Protection Agency  
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PB00101*ID	OH0021300	6/15/2011	C	S	1

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Georgetown WWTW 1500 Influent Drive Georgetown, Brown County	9:30 a.m.	9/1/2010
	Exit Time	Permit Expiration Date
	2:30 p.m.	5/31/2015
Name(s) and Title(s) of On-Site Representatives		Phone Number(s)
Derek Copas, Operator of Record		937-937-378-3718
Name, Address and Title of Responsible Official		Phone Number
Mayor & Council Municipal Bldg. 301 South Main Street Georgetown, OH 45121		937-378-4896

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	S	Flow Measurement	N	Pretreatment
S	Records/Reports	*	Laboratory	U	Compliance Schedule
S	Operations & Maintenance	U	Effluent/Receiving Waters	S	Self-Monitoring Program
M	Facility Site Review	S	Sludge Storage/Disposal	N	Other
U	Collection System				

\*Evaluated but not rated.

Section D: Summary of Findings (Attach additional sheets if necessary)			
See Attached.			
Inspector		Reviewer	
	6-29-11		6/29/11
Joshua Jackson Division of Surface Water Southwest District Office	Date	Debora Roth, P.E. Permits Supervisor Division of Surface Water Southwest District Office	Date