



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PB0004420090420

BROWN

MT ORAB WWTP

JACKSON, JOSHUA 2009/04/20



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

April 20, 2009

Mayor & Council
Village of Mt. Orab
P.O. Box 466
Mt. Orab, OH 45154

(copy)

**RE: Village of Mt. Orab wastewater treatment works/ self-monitoring violations
NPDES Permit No. OH0026646/OEPA PERMIT NO. 1PB00044*CD**

major: (copy)

Dear Mr. Colwell:

We have reviewed your self-monitoring reports covering the months of December 2008 through March 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit. The specific instances of noncompliance were as follows:

**EFFLUENT LIMIT VIOLATIONS
(Period of Review: December 2008 – March 2009)**

7D = Weekly 30D = Monthly 1D = Daily Conc. = Concentration (mg/l) Qty. = Quantity (Kg/Day)

Reporting Period	Parameter	Limit Type	Limit	Reported Value
December 2008	Total Suspended Solids	7D Qty	47.7	80.9249
December 2008	pH	1D Conc	6.5	6.25
February 2009	Total Suspended Solids	30D Conc	12	15.825
February 2009	Total Suspended Solids	30D Qty	31.8	33.5101
February 2009	Nitrogen, Ammonia (NH3)	30D Conc	2.0	2.8525
February 2009	Nitrogen, Ammonia (NH3)	7D Conc	3.0	3.175
February 2009	Nitrogen, Ammonia (NH3)	30D Qty	5.3	5.88557
February 2009	Total Suspended Solids	7D Conc	18	39.
February 2009	Total Suspended Solids	7D Qty	47.7	60.2647
February 2009	Nitrogen, Ammonia (NH3)	7D Conc	3.0	5.255
March 2009	Total Suspended Solids	7D Qty	47.7	72.8167

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Mayor & Council
Page 2

response already given

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at Joshua.Jackson@epa.state.oh.us.

Respectfully,



Joshua Jackson
Environmental Specialist II
Division of Surface Water

cc: John Van Harlingen, The H2O Company