



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PS0001320070709

BROWN WAYNOKA REGIONAL WATER

POHLMAN, LAURA 2007/07/09



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 9, 2007

George Culver, Superintendent
Waynoka Regional Water
Lot 2697 Wanna Drive
Sardinia, Ohio 45171

**Re: Brown County, Waynoka Regional Water
NPDES No. 1PS00013*DD / OH000115771
Self-Monitoring Report Notice of Violation – January 2007 through May 2007**

Dear Mr. Culver:

We have reviewed your Monthly Operating Reports (MORs) covering the months of January 2007 through May 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH000115771; OEPA Permit # 1PS00013*DD). The specific instance(s) of noncompliance and/or deficiencies were as follows:

Effluent Limit Violations For Outfall 001					
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value
January 2007	001	CBOD5	30D Conc	10	10.7
January 2007	001	pH	1D Conc	9.0	9.4
January 2007	001	pH	1D Conc	9.0	9.4
January 2007	001	pH	1D Conc	9.0	9.4
January 2007	001	pH	1D Conc	9.0	9.4
January 2007	001	pH	1D Conc	9.0	9.1

Effluent Limit Violations For Outfall 602					
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value
January 2007	602	TSS	30D Conc	12	141
January 2007	602	TSS	7D Conc	18	276

Mr. George Culver
July 9, 2007
Page 2


Frequency Violations For Outfall 001						
Reporting Period	Violation Date	Station	Parameter	Sample Frequency	Expected	Reported
January 2007	1/1/2007	001	Water Temp.	2/Week	2	0
January 2007	1/1/2007	001	TSS	2/Week	2	0
January 2007	1/1/2007	001	CBOD5	2/Week	2	0
January 2007	1/1/2007	001	Phosphorus, Total	1/2Weeks	1	0
January 2007	1/1/2007	001	pH	2/Week	2	0
January 2007	1/1/2007	001	DO	2/Week	2	0

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,



Laura Pohlman
Division of Surface Water
Permit Section

Cc: Timothy O'Farrell