



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director



\*1PR0000220081029\*

BUTLER

BROWN'S RUN COUNTRY CLUB

SARLE, EDWARD

2008/10/29

Savage



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 29, 2008

Mr. Gregory Martin  
Brown's Run Country Club  
6855 Sloebig Road  
Middletown, Ohio 45042

Re: Butler County, Brown's Run Country Club, NPDES Permit Violations

Dear Mr. Martin:

We have reviewed your Monthly Operating Reports (MORs) covering the months of April through September 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0085669; OEPA Permit # 1PR00002\*BD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
June 2008	TSS	Monthly	mg/l	12	15
June 2008	Chlorine	Daily	mg/l	0.019	0.6
August 2008	TSS	Monthly	mg/l	12	20
August 2008	TSS	Weekly	mg/l	18	20
August 2008	Chlorine	Daily	mg/l	0.019	1.3

In addition, the PTI application for the Brown's Run Country Club WWTP upgrade was approved on August 28, 2007. This approval will expire if construction is not started within 18 months of the effective date of the permit. If construction can not be started within 18 months, the applicant may request a one time extension of an additional 12 months. However, the WWTP upgrade still must be constructed as soon as possible to eliminate these violations. Please indicate the status of this construction.


Please be advised that failure to comply with the effluent limitations or to satisfy the reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Mr. Greg Martin  
October 29, 2008  
Page 2

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



Ned Sarle  
Division of Surface Water  
Permit Section