



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director



\*1PV0009520070829\*

BUTLER

CROUSE MHP \*

SARLE, EDWARD

| 2007/08/29



## State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 29, 2007

Mr. Brian Bremer  
Crouse MHP  
4141 Hamilton Eaton Road  
Hamilton, Ohio -45011

Re: Butler County, Crouse MHP, NPDES Permit Violations

Dear Mr. Bremer:

We have reviewed your Monthly Operating Reports (MORs) covering the months of December 2006 through July 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0118923; OEPA Permit # 1PV00095\*CD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
February 2007	Ammonia	Monthly	mg/l	5.0	8.8
February 2007	Ammonia	Weekly	mg/l	7.5	12.9
May 2007	Chlorine	Daily	mg/l	0.034	0.08
June 2007	Chlorine	Daily	mg/l	0.034	0.08
June 2007	Chlorine	Daily	mg/l	0.034	0.08
June 2007	Chlorine	Daily	mg/l	0.034	0.08
June 2007	Chlorine	Daily	mg/l	0.034	0.08
June 2007	Chlorine	Daily	mg/l	0.034	0.08
June 2007	Chlorine	Daily	mg/l	0.034	0.08
June 2007	Chlorine	Daily	mg/l	0.034	0.05
June 2007	Chlorine	Daily	mg/l	0.034	0.05
June 2007	Chlorine	Daily	mg/l	0.034	0.05
June 2007	Chlorine	Daily	mg/l	0.034	0.05
June 2007	Chlorine	Daily	mg/l	0.034	0.05
June 2007	Chlorine	Daily	mg/l	0.034	0.05
June 2007	pH	Daily	mg/l	9.0	9.5
June 2007	pH	Daily	mg/l	9.0	9.5

Mr. Brian Bremer  
August 29, 2007  
Page 2

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
June 2007	pH	Daily	mg/l	9.0	9.5
June 2007	pH	Daily	mg/l	9.0	9.5
June 2007	pH	Daily	mg/l	9.0	9.5
July 2007	Chlorine	Daily	mg/l	0.034	0.05
July 2007	Chlorine	Daily	mg/l	0.034	0.07

Numerous monitoring violations were noted for the chlorine residual. This parameter must be monitored and reported on a daily basis.

Please be advised that failure to comply with the effluent limitations or to satisfy the reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have received your reports addressing the violations for February 2007 and the actions being taken to prevent further occurrences. However, reports were not submitted for the remaining violations. Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



~~Ned Sarle~~  
Division of Surface Water  
Permit Section

cc: Andy Griner, Winelco, Inc.