



**Environmental  
Protection Agency**

**Ted Strickland**, Governor  
**Lee Fisher**, Lt. Governor  
**Chris Korleski**, Director



\*1PV0009520071120\*

BUTLER

CROUSE MHP \*

POHLMAN, LAURA

2007/11/20



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

November 20, 2007

Mr. Brian Bremer  
Crouse MHP  
4141 Hamilton Eaton Road  
Hamilton, Ohio 45011

**Re: Butler County, Crouse MHP, NPDES Permit Violations**

Dear Mr. Bremer:

We have reviewed your Monthly Operating Reports (MORs) covering the months of July through September 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0118923; OEPA Permit # 1PV00095\*CD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations				
Reporting Period	Parameter	Limit Type	Limit	Reported Value
July 2007	Chlorine, Total Res.	1D Conc	0.034	.05
July 2007	Chlorine, Total Res.	1D Conc	0.034	.07
August 2007	Chlorine, Total Res.	1D Conc	0.034	.07

Numerous monitoring violations were noted for the chlorine residual and Nitrogen, Ammonia. This parameter must be monitored and reported on a daily basis.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason(s) for the above referenced violation(s), as well as a description of the action(s) taken or proposed to prevent any further violation(s). Your response should include the dates, either actual or proposed, for completion of the action(s). Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

Mr. Brian Bremer  
November 20, 2007  
Page 2

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,

A handwritten signature in cursive script that reads "Laura Pohlman". The signature is written in black ink and is positioned above the printed name.

~~Laura Pohlman~~  
Division of Surface Water  
Permit Section

cc: Andy Griner, Winelco, Inc.