



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PD0000320110107

BUTLER

FAIRFIELD WWTP

SARLE, EDWARD

2011/01/07

Fairfield WWT
Lawage

**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Koneski, Director

January 7, 2011

Mr. Dave Crouch
City of Fairfield
5350 Pleasant Avenue
Fairfield, Ohio 45014

Re: Butler County, City of Fairfield, Compliance Evaluation Inspection

Dear Mr. Crouch:

On January 4, 2011, I conducted a Compliance Evaluation Inspection at this facility (NPDES Permit No. OH0025071, OEPA Permit No. 1PD00003*OD). Representing this facility was Drew Young, Jason Hunold and Linda Moubray. A copy of my inspection report is enclosed.

All areas evaluated in the inspection report were found to be acceptable. At this time, all areas noted in the inspection report are being addressed. Therefore, no response is required at this time.

If you have any questions, please call me at (937) 285 - 6096.

Sincerely,



Ned Sarle
Division of Surface Water
Permits Group

Enclosures

cc: Drew Young, City of Fairfield






State of Ohio Environmental Protection Agency
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PD00003*OD	OH0025071	1/4/2011	C	S	1

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Fairfield WWTP 4799 Groh Lane Fairfield, Ohio 45014	9:30 A.M.	12/1/2009
	Exit Time	Permit Expiration Date
	2:30 P.M.	7/31/2014
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Drew Young, Public Utilities Superintendent	(513) 858-7760	
Jason Hunold, Chief Operator	(513) 858-7760	
Linda Moubray, Lab Supervisor	(513) 858-7760	
Name, Address and Title of Responsible Official	Phone Number	
David E. Crouch, Public Utilities Director 5350 Pleasant Avenue Fairfield, Ohio 45014	(513) 867-5375	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	S	Flow Measurement	N	Pretreatment
S	Records/Reports	S	Laboratory	S	Compliance Schedule
S	Operations & Maintenance	S	Effluent/Receiving Waters	S	Self-Monitoring Program
S	Facility Site Review	S	Sludge Storage/Disposal	N	Other
S	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)	
See Attached Summary of Findings / Comments.	
Inspector	Reviewer
 Ned Sarle Division of Surface Water Southwest District Office	 Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office
1/7/11 Date	1/7/11 Date

Permit #: 1PD00003*OD
NPDES #: OH0025071

Sections E thru K: Complete on all inspections as appropriate
Y – Yes, N – No, N/A – Not Applicable, N/E – Not Evaluated

Section E: Permit Verification

Inspection observations verify the permit

- (a) Correct name and mailing address of permittee Y
- (b) Flows and loadings conform with NPDES permit..... Y
- (c) Treatment processes are as described in permit application... Y
- (d) All discharges are permitted..... Y
- (e) Number and location of discharge points are as described
in permit..... Y
- (f) Storm water discharges properly permitted..... Y

Comments/Status:

The site is covered by a General Industrial Storm Water NPDES Permit. See Attached Summary of Findings / Comments for additional information.

Section F: Compliance

- (a) Any significant violations since the last inspection..... Y
- (b) Appropriate Non-compliance notification of violations..... Y
- (c) Permittee is taking actions to resolve violations..... Y
- (d) Permittee has a compliance schedule..... N
- (e) Compliance schedule contained in...N/A
- (f) Permittee is in compliance with schedule..... N/A
- (g) Has biomonitoring shown toxicity in discharge since last inspection N

Comments/Status:

See Attached Summary of Findings / Comments.

Section G: Operation & Maintenance

Treatment Works:

Treatment facility properly operated and maintained

(a) Standby power available.....generator or dual feed Y

i. What does the back-up power source operate.....

The dual power feed serves the whole WWTP. The City of Fairfield is still looking at installing a backup generator. However, this will not likely occur for several years.

ii. How often is the generator tested under load.....

N/A.

(b) Which components have an alarm system available for power or equipment failures.....

The influent pump station, pretreatment system, aeration treatment system, secondary clarifiers and ultraviolet disinfection.

(c) All treatment units in service other than backup units..... Y

(d) What method is used for scheduling routine & preventative maintenance (calendar, software, etc.).....

Computer program.

(e) Any major equipment breakdown since last inspection..... N

(f) Operation and maintenance manual provided and maintained..... Y

(g) Any plant bypasses since last inspection..... N

(h) Any plant upsets since last inspection..... Y

Comments/Status:

None.

Section G: Operation & Maintenance con't

Record Keeping/Operator of Record:

- (a) Wastewater Treatment Works classification (OAC 3745-7)..... IV
- (b) Operator of Record holds unexpired license of class required by Permit..... Y
- (c) Copy of certificate of Operator of Record displayed on-site..... Y
- (d) Has the Operator of Record submitted an ORC Notification form. Y
- (e) Minimum operator staffing requirements fulfilled (OAC 3745-7).... Y
- (f) If a Staffing Reduction plan has been approved, are the stipulations of the plan being met..... N/A
- (g) Operator of Record log book provided..... Y
- (h) Format of log book (e.g. computer log, hard bound book)

Computer system.
- (i) Log book kept onsite (in an area protected from weather)..... Y
- (j) Log book contains the following:
 - I. Identification of treatment works..... Y
 - II. Date/times of arrival/departure for Operator of Record and any other operator required by OAC 3745-7..... Y
 - iii. Daily record of operator and maintenance activities (including preventative maintenance, repairs and request for repairs, process control test results, etc.)..... Y
 - iv. Laboratory results (unless documented on bench sheets)... Y
 - v. Identification of person making entries..... Y
- (k) Has the Operator of Record submitted written notifications to the permittee, Ohio EPA and, if applicable, any local environmental agencies when a collection system overflow, treatment plant bypass or effluent limit violation has occurred..... Y

Comments/Status:

None.

Section G: Operation & Maintenance con't

Collection System:

- (a) Are there pump stations in the collection system..... Y
 - i. How many publicly-owned pump stations equipped with permanent standby power or equivalent.....11
 - ii. How many pump stations have telemetered alarms.....13
 - iii. How many pump stations have operable alarms.....13

- (b) Any chronic collection system overflows since last inspection..... N
- (c) Regulatory agency notified of all overflows..... N/A
- (d) Are there CSOs in the collection system..... N/A
if so, what is the LTCP status.....
- (e) How are CSOs monitored (chalk, block, level sensor, etc.).....
- (f) Portable pumps available for collection system maintenance..... Y
- (g) RDII Program established and active..... Y
- (h) Any WIB complaint received since last inspection..... N
- (i) Is there a WIB response plan..... Y
- (j) Is any portion of the collection system at or near dry weather capacity..... N

Comments/Status:

The community has one six inch pump and four three inch pumps that may be used for the collection system maintenance. See Attached Summary of Findings / Comments for additional information.

Section H: Sludge Management

(a) Method of Sludge Disposal...

- Land Application
- Haul to Another NPDES Permittee
- Haul to a Mixed Solid Waste Landfill

*if one of the selected methods is land application, complete applicable charts.

Class A - Exception Quality Sewage Sludge (monitoring station 584)

Pathogen Reduction Alternative	84370 Vector Attraction Reduction Options							
	Option 1 -38% Volatile Solids Reduction	Option 2 -Anaerobic Bench Scale Analysis	Option 3 - Aerobic Bench Scale Analysis	Option 4 - Specific Oxygen Uptake Rate	Option 5 - Aerobic Time and Temperature	Option 6 - Alkali Addition	Option 7 - >75% Percent Solids without Unstabilized Solids	Option 8 - >75% Percent Solids with Unstabilized Solids
Alternative 1 - Time and Temperature Regime (84369)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 2 - High pH and High Temperature (84369)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 3 - Other Processes (84369)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 4 - Unknown Processes (84369)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 - Composting (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 - Heat Drying (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 - Heat Treatment (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 - Thermophilic Aerobic Digestion (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 - Beta Ray Irradiation (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 - Gamma ray Irradiation (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 5 - Pasteurization (84397)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 6 - Approved Equivalent Process	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Permit #: 1PD00003*OL
 NPDES #: OH0025071

Class B Sewage Sludge (monitoring station 581)

Pathogen Reduction Alternative	84370 Vector Attraction Reduction Options									
	Option 1 -38% Volatile Solids Reduction	Option 2 -Anaerobic Bench Scale Analysis	Option 3 - Aerobic Bench Scale Analysis	Option 4 - Specific Oxygen Uptake Rate	Option 5 - Aerobic Time and Temperature	Option 6 - Alkali Addition	Option 7 - >75% Percent Solids without Unstabilized	Option 8 - >75% Percent Solids with Unstabilized	Option 9 - Land Injection	Option 10 - Immediate Incorporation
Alternative 1 - Geometric Mean of Seven Fecal Samples (84369)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 2 - Aerobic Digestion (46396)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 2 - Air Drying (46396)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 2 - Anaerobic Digestion (46396)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 2 - Composting (46396)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 2 - Lime Treatment (46396)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternative 3 - Approved Equivalent Process	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

- (b) Has amount of sludge generated changed significantly since the last inspection..... N
- (c) How much sludge storage is provided at the plant.....
- (d) Records kept in accordance with State and Federal law (5 years according to OAC 3745-40-06)..... Y
- (e) Any complaints received in last year regarding sludge..... N
- (f) 5/8" screen at headworks for facilities that land apply sludge..... Y
- (g) Are sludge application sites inspected to verify compliance with NPDES permit..... Y
- (h) Is a contractor used for sludge disposal..... Y
 If so, what is the name of the contractor.....

Comments/Status:

Section I: Self-Monitoring Program

Flow Measurement:

- (a) Primary/Secondary flow measuring devices (e.g. weir with ultrasonic level sensor):
- (b) Flow meter calibrated annually Y
(Date of last calibration: 11/9/2010)
- (c) 24-hour recording instruments operated and maintained..... Y
- (d) Flow measurement equipment adequate to handle full range of flows..... Y
- (e) All discharged flow is measured..... Y

Comments/Status:

Flow monitoring equipment is capable of measuring between 0 and 33 MGD.

Section I: Self-Monitoring Program (con't)

Sampling:

- (a) Sampling location(s) are as specified by permit..... Y
- (b) Parameters and sampling frequency agree with permit..... Y
- (c) Permittee uses required sampling method..... Y
(see GLC page)
- (d) Monitoring records (i.e., flow, pH, DO) maintained for a minimum of three years including all original strip chart recordings (i.e, continuous monitoring instrumentation, calibration and maintenance records)..... Y

Comments/Status:

None.

Section I: Self-Monitoring Program (con't)

Laboratory:

General

(a) Does the Quality Assurance Manual contain written Standard Operating Procedures (SOP's) for all analysis performed onsite..... Y

(b) Do SOP's include the following if applicable..... Y

- Title
- Scope and Application
- Summary
- Sample Handling and Preservation
- Interferences
- Apparatus and Materials
- Reagents
- Procedure
- Calculations
- Quality Control
- Maintenance
- Corrective Action
- Reference (Parent Method)

Note: Standard Methods 1020A establishes that "Quality assurance (QA) is the definitive program for laboratory operation that specifies the measure required to produce defensible data of known precision and accuracy. Standard operating procedures are to be used in the laboratory in sufficient detail that a competent analyst unfamiliar with the method can conduct a reliable review and/or obtain acceptable results." SOPs should be developed for each analytical procedure.

(c) EPA approved analytical testing procedures used (40 CFR 136.3).. Y

(d) If alternate analytical procedures are used, proper approval has been obtained..... N/A

(e) Analyses being performed more frequently than required by permit. Y

(f) If (e) is yes, are results in permittee's self-monitoring report..... Y

(g) Satisfactory calibration and maintenance of instruments/equipment. Y
(see score from GLC page)

(h) Commercial laboratory used..... Y

Parameters analyzed by commercial lab: Metals, sludge parameters, nitrate, nitrites, phosphorus, TKN, cyanide, Oil & Grease, mercury and biomonitoring.

Lab name: Test America and Enviroscience.

Discharge Monitoring Report Quality Assurance (DMRQA)

(a) Participation in latest USEPA quality assurance performance sampling..... Y

Date:

(b) Were any parameters "Unsatisfactory"..... Y

(c) Reasons for "Unsatisfactory" parameters.....

TSS - Laboratory error.

Comments/Status:

None.

Section J: Effluent/Receiving Water Observations

Outfall # 001

Outfall Description: Effluent pipe discharge.

Receiving Stream: Great Miami River

Receiving Stream Description: No adverse conditions were noted.

Comments/Status:

Outfall sign has been posted as required by the NPDES Permit.

Section K: Multimedia Observations

- (a) Are there indications of sloppy housekeeping or poor maintenance in work and storage areas or laboratories..... N
- (b) Do you notice staining or discoloration of soils, pavement or floors.. N
- (c) Do you notice distressed (unhealthy, discolored, dead) vegetation.. N
- (d) Do you see unidentified dark smoke or dust clouds coming from sources other than smokestacks..... N
- (e) Do you notice any unusual odors or strong chemical smells..... N
- (f) Do you see any open or unmarked drums, unsecured liquids, or damaged containment facilities..... N

If any of the above are observed, ask the following questions:

- (1) What is the cause of the condition?
- (2) Is the observed condition or source a waste product?
- (3) Where is the suspected contaminant normally disposed?
- (4) Is this disposal permitted?
- (5) How long has the condition existed and when did it begin?

Comments/Status:

None.

Permit #: 1PD00003*OL
NPDES #: OH0025071

Summary of Findings / Comments

A review of the Monthly Operating Reports (MORs) for March through November 2010 indicated one violation. This violation is listed on Attachment I. At this time, the Fairfield WWTP has adequately addressed these violations. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

The Fairfield WWTP is designed to treat an average daily flow (ADF) of 10.0 MGD and a peak daily flow (PDF) of 18.0 MGD. For noted period, the ADF was 4.817 MGD, and the PDF was 11.095 MGD. No sewage collection system or WWTP bypasses were reported for this period.

The sanitary sewer system consists of 175 miles of gravity sanitary sewers and 13 pump stations. The sanitary sewers are cleaned an average of once every five years. Sanitary sewers are visually inspected once every ten years. Sources of I/I are eliminated as found. A sewage collection system hydraulic model has also been completed. Fairfield must continue their efforts to minimize I / I into the sanitary sewer. No Water in Basement incidents were reported for 2010. All future sewage collection system bypasses must be reported in accordance to the NPDES Permit as detailed in Part III, Section 11 titled "Unauthorized Discharges."

Sludge is land applied by Oros and Busch. In 2010, 506 dry tons of sludge were land applied. Sludge was not hauled to the landfill during the year.

A Bio Win model of the Fairfield WWTP has been completed. This model will be used to consider different treatment conditions and how they may assist in nutrient reduction.

The Operator of Record is Drew Young, and he is a Class IV operator. Jason Hunold is a Class III operator. Finally, several other Class III operators are present at the WWTP.

Permit #: 1PD00003*OD
NPDES #: OH0025071

Attachment I

Effluent Limit Violations for March through November 2010

Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
October 2010	Ammonia	Weekly	mg/l	2.4	2.5

General Lab Criteria

Criteria	Standard Methods Requirement		Rating
Balance	Acceptable?		A
• Standard Weights	• Either NIST Class S or ASTM/ANSI Class 1 weights ^{1,2}	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Calibration Frequency / Documentation	• Calibration verification required at least once each day the balance is used. ³	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Cleanliness, air movement, vibration	• Cleanliness of balance is a must and air movement and vibration needs to be kept to a minimum ¹	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Service and recalibrate annually (manufacturer representative or comparable) ¹	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Must be able to measure to 0.1 grams ⁴	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Instrument manual available	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Log book maintained ²			<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Comments: : None.			
Criteria	Standard Methods Requirement		Rating
Drying Oven (Suspended Solids)	Acceptable?		A
• Temperature Recordkeeping	• Temperature recorded with each use ⁴	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Log book maintained ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Calibration Frequency / Documentation	• Thermometer calibrated annually with NIST traceable thermometer ^{1,2} . Correction factor posted on thermometer / equipment ¹	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Thermometer temperature accurate to 0.5° Celsius ⁵	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Acceptable temperature range is 103° – 105° C ⁴	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Instrument manual available	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Comments: : None.			

General Lab Criteria

Criteria	Standard Methods Requirement	Acceptable?		Rating
pH Meter				
• Calibration Frequency / Documentation	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples) ³	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	A
	• Logbook maintained ²	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Minimum of 2 point calibration	• Calibration per manufacturer specification and calibration buffers must bracket anticipated result ⁷	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Slope Documentation / Acceptability	• Slope acceptable range indicated on benchsheet ²	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Buffer Expiration Date	• Buffers must not be expired	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Instrument manual available	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Teflon covered magnetic stirrer or equivalent for mixing ⁸	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments: : None.				

Criteria	Standard Methods Requirement	Acceptable?		Rating
Dissolved Oxygen Meter				
• Calibration Method	• Air or known DO calibration method ¹⁰	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	A
	• Calibration per manufacturer specification ¹⁰	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Calibration Frequency / Documentation	• Logbook maintained ²	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Calibration verification required at least once each day the meter is used. ³	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Small to no bubble present under membrane (must be smaller than the lead in number 2 pencil) ¹¹	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments: None.				

General Lab Criteria

Criteria	Standard Methods Requirement		Rating
Incubator (CBOD/ E-Coli)			
		Acceptable?	
• Temperature Recordkeeping	• Temperature checked / recorded twice daily for each shelf in use ¹ (E-Coli)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	A
	• Temperature checked / recorded daily ² (CBOD)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Acceptable temperature range (CBOD) is 20° C ±1.0° ¹²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Acceptable temperature range (E-Coli) is 35° C ±0.5° ²²	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Logbook maintained ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer ^{1, 2}	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Temperature correction information posted on incubator ¹	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• E-Coli can use multiple tubes (five 20 ml or ten 10 ml), or mfg's multi-well tray	• E-coli Ultraviolet lamp (365 nm wave length, 6 W bulb) ²³	<input type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Instrument manual available	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Temperature Log (thermometer accurate to 0.5 Celsius). ¹	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Comments: : None.

Criteria	Standard Methods Requirement		Rating
Refrigerator			
		Acceptable?	
• Temperature Recordkeeping	• Temperature Log (thermometer accurate to 0.5 Celsius). ⁵	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	A
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer ^{1, 2}	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Thermometer held in water bath. ¹	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Refrigerator temperature ≤6° Celsius. ¹³	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Do not store volatile solvents, food, or beverages. ¹⁴	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Comments: None.

General Lab Criteria

Criteria	Standard Methods Requirement	Acceptable?		Rating
Chlorine Meter				
• Calibration Frequency / Documentation	• pH / millivolt meter read to 0.1 mV ¹⁵	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples) ³	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Calibration Method	• Calibration using three iodate solutions 0.2, 1.0, 5.0 milliliters or calibration per manufacturer specification ¹⁶	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Standards used for calibration not expired	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Slope Documentation / Acceptability	• Calibration curve (acceptable slope)	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Electrode free of deposits and foreign material	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book being maintained. ²	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments: :				

Criteria	Standard Methods Requirement	Acceptable?		Rating
Ammonia Meter				
• Calibration Frequency / Documentation	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples) ³	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	A
	• Log book being maintained ²	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Slope acceptability	• Verify calibration slope is acceptable (per mfg. spec.).	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Calibration Method	• Standards used for calibration (3 ammonia solutions of 10 mg/l, 1 mg/l, and 0.1 mg/l) or per mfg. spec. ¹⁷	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Standards used for calibration not expired	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Electrode free of deposits and foreign material	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Teflon covered magnetic stirrer or equivalent for mixing ¹⁸	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments: : None.				

General Lab Criteria

Criteria	Standard Methods Requirement		Rating
Sample Collection/Handling	Acceptable?		
• Sample Labeling	• Samples container labeled (description, date, time, preservative added, initialed). ¹⁹	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	A
• Chain of Custody	• Chain of custody (description, date, time, signature). ¹⁹	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Composite samples refrigerated during sample collection ¹⁴	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Equipment blanks utilized ¹⁴	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	• SOP for cleaning of sampling equipment	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Logbook being maintained ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Comments: None.

Criteria	Standard Methods Requirement		Rating
Desiccator	Acceptable?		
• General criteria	• Properly working seals.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	A
	• Desiccant fresh (blue color)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Documentation	• Log book being maintained ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Comments: None.

Criteria	Standard Methods Requirement		Rating
Bench sheets	Acceptable?		
• General criteria	• Date(s) ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	A
	• Analyst initials ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Blue or black ink pen ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Calibration information ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Equations, calculations, units for all measurements, notations, and results present ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Corrections, single line through, initialed and dated ²	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Comments: None.

General Lab Criteria

Criteria	Standard Methods Requirement	Acceptable?		Rating
Hot Water Bath (Fecal Coliform/E. Coli)				
• Temperature Recordkeeping	• Temperature Log (thermometer accurate to 0.2° C) ²¹	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Incubator temperature 44.5° C ± 0.2° ^{21/24}			
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer ^{1, 2}	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book being maintained ²	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Water Level	• Thermometer total immersion or partial (line on thermometer to ID immersion depth) ^{1, 5}	<input type="checkbox"/> Yes	<input type="checkbox"/> No	

Comments: Not applicable for fecal coliform test being performed by the city.

Criteria	Standard Methods Requirement	Acceptable?		Rating
Autoclaves/Steam Sterilizers				
• All apparatus utilized is adequately sterilized before use	• Sterilizing temperature 121° C ²⁵	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	A
	• 10 to 30 minutes time based on material being sterilized ²⁶	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Documentation	• Verify the autoclave temperature weekly by using a maximum registering thermometer (MRT) to confirm that 121°C has been reached as measured in the exhaust. ¹	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Date, contents, sterilization time and temperature, total time in autoclave, and analyst's initials should be recorded each time the autoclave is used ¹	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer ^{1,2}	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book being maintained ²	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Performance Checks	• Test monthly for efficacy using a biological such as commercially available <i>Geobacillus stearothermophilus</i> in spore strips, suspensions, or capsules ¹	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	

Comments: None.

General Lab Criteria

Criteria	Standard Methods Requirement		Rating
Final Effluent Temperature Monitoring		Acceptable?	
• General Criteria	• Thermometer calibrated annually with NIST traceable thermometer ^{1,2}	<input type="checkbox"/> Yes	<input type="checkbox"/> No
	• Thermometer accurate to 0.1° Celsius ⁵	<input type="checkbox"/> Yes	<input type="checkbox"/> No
	• Log book being maintained ²	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Comments: Area not evaluated.			
Number of Criteria Rated:			Acceptable
			11
			Marginal
			0
			Unacceptable
			0
			Total Number of Areas Rated
			11
<p>Acceptable Ratings – No action required (recommend SOP's written or updated, perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, written response not required).</p>			
<p>Marginal Ratings – Improvements required, written response required (recommend SOP's be written or updated, recommend they perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, require deficiencies to be addressed in written response).</p>			
<p>Unsatisfactory Rating - Improvements required, written response required, NOV issued (recommend SOP's be written or updated, recommend they perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, require deficiencies to be addressed in written response to NOV).</p>			
Consider recommending PAI Audit from DES when:		>60% of ratings are Marginal >45% of ratings are a combination of Marginal or Unacceptable >30% of ratings are Unacceptable	

Notation of Referenced Method

- | | |
|----------------------------|------------------------------|
| 1 Method 9020-B, Item 3 | 14 Method 1060A, Item 1 |
| 2 Method 1020-A, Item 1 | 15 Method 4500-CI I, Item 2 |
| 3 Method 1020-B, Item 10 | 16 Method 4500-CI I, Item 4 |
| 4 Method 2540-B, Item 2 | 17 Method 4500-NH3 D, Item 4 |
| 5 Method 2550-B, Item 1 | 18 Method 4500-NH3 D, Item 2 |
| 6 Method 1020-A, Item 1 | 19 Method 1060-B, Item 2 |
| 7 Method 4500-H B, Item 4 | 20 Method 1060-B, Item 1 |
| 8 Method 4500-H B, Item 2 | 21 Method 9222D, Item 1 |
| 9 Method 1020-B, Item 2 | 22 Method 9223 B, Item 2 |
| 10 Method 4500-O B, Item 3 | 23 Method 9223 B, Item 3 |
| 11 Method 4500-O G, Item 3 | 24 Method 1603, Item 2 |
| 12 Method 5210-B, Item 5 | 25 Method 9030-B, Item 3 |
| 13 CFR 136.3, Table II | 26 Method 9020 B, Table IV |

Equipment Logbook Content - all maintenance performed on a piece of equipment should be documented in the logbook. This should include parts replacement and routine maintenance activities. Entries should include date, maintenance performed and initials of person making entry.

General Lab Criteria

Preservation and Holding Times

Parameter	Container	Min. Sample Size (mL)	Sample Type	Preservation	Maximum Storage Time	
					Recommended	Regulatory
BOD / CBOD	P, G	1000	G, C	Refrigerate $\leq 6^{\circ}\text{C}$	6h	48h
TSS	P, G	200	G, C	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 d
pH	P, G	50	G	Analyze immediately	0.25h	0.25 h
NH ₃ -N	P, G	500	G, C	Analyze as soon as possible or add H ₂ SO ₄ to pH <2, Refrigerate $\leq 6^{\circ}\text{C}$	7 d	28 d
TRC	P, G	500	G	Analyze immediately	0.25h	0.25 h
DO (electrode)	G, BOD Bottle	300	G	Analyze immediately	0.25h	0.25 h
Temperature	P, G	--	G	Analyze immediately	0.25h	0.25 h
Metals, general	P, G	1000	G, C	For dissolved filter immediately and add HNO ₃ to pH <2	6 months	6 months
Purgeables by purge and trap	G (PTFE lined lid)	40 (X2)	G	HCl to pH<2, Refrigerate $\leq 6^{\circ}\text{C}$	7 d	14 d
Base/Neutrals and acids	G (solvent rinsed or baked)	1000	C, G	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 days until extraction 40 days after extraction
Pesticides	G (PTFE lined lid)	1000	C	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 days until extraction 40 days after extraction
Fecal Coliform / E-Coli	G, P (Sterilized)	100	G	Refrigerate $\leq 10^{\circ}\text{C}$ If chlorine present, add sodium thiosulfate tablet	6 hrs transport Start analysis within 2 hrs of receipt in lab.	
Oil and Grease	G	1000	G	HCl or H ₂ SO ₄ to pH <2, Refrigerate $\leq 6^{\circ}\text{C}$	28 d	28 d

Approved Standard Methods

CBOD / BOD 5 Day	Std Methods 5210-B
Ammonia, Selective Electrode Method	Std Methods 4500-NH ₃ D
Total Residual Chlorine, DPD Colorimetric Method	Std Methods 4500-Cl G
Total Suspended Solids, Dried at 103-105 °C	Std Methods 2540-D
Dissolved Oxygen, Membrane Electrode Method	Std Method 4500-O G
pH, Electrometric Method	Std Methods 4500-H+ B
Fecal Coliform, Membrane Filter Procedure	Std Methods 9222D
Escherichia Coli, Enzyme Substrate Test	Std Method 9223B
Escherichia Coli Membrane Filtration Procedure	EPA Method 1603
Oil and Grease	USEPA 1664A or Std Methods 5520B
Metals, general	USEPA 200, Std Methods 3111B or C, or 3120B
Volatiles (Purgeables by purge and trap)	USEPA 6210, Std Methods 624
Semi-Volatiles (Base/Neutrals and acids)	USEPA 6410, Std Methods 625
Pesticides	USEPA 6410 and 6630, Std Methods 608