



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PT0007920070829

BUTLER GOLDEN YEARS HEALTHCARE WWTP

SARLE, EDWARD 2007/08/29

Sewage



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 29, 2007

Ms. Kyra Hornsby
CHS Oxford Inc.
2436 Old Oxford Road
Hamilton, Ohio 45013

Re: Butler County, Golden Years Healthcare, NPDES Permit Violations

Dear Ms. Hornsby:

We have reviewed your Monthly Operating Reports covering the months of May through July 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0118397; OEPA Permit # 1PT00079*CD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
May 2007	Fecal Coliform	Monthly	#/100ml	1000	1400
May 2007	TSS	Monthly	mg/l	12	24
May 2007	Chlorine	Daily	mg/l	0.019	0.08
May 2007	TSS	Weekly	mg/l	18	24
June 2007	TSS	Monthly	mg/l	12	29
June 2007	TSS	Weekly	mg/l	18	29
June 2007	Chlorine	Daily	mg/l	0.019	0.4
June 2007	Chlorine	Daily	mg/l	0.019	0.1
July 2007	Chlorine	Daily	mg/l	0.019	0.05
July 2007	Chlorine	Daily	mg/l	0.019	0.15
July 2007	Chlorine	Daily	mg/l	0.019	0.1


Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Ms. Kyra Hornsby
August 29, 2007
Page 2

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,




Ned Sarle
Division of Surface Water
Permit Section

cc: Frank Shuler, BHE Environmental