



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PT0007920080424

BUTLER

GOLDEN YEARS HEALTHCARE WWTP

SARLE, EDWARD

2008/04/24



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 24, 2008

Ms. Kyra Hornsby
CHS Oxford Inc.
2436 Old Oxford Road
Hamilton, Ohio 45013

Re: Butler County, Golden Years Healthcare, NPDES Permit Violations

Dear Ms. Hornsby:

We have reviewed your Monthly Operating Reports covering the months of October 2007 through February 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0118397; OEPA Permit # 1PT00079*CD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
October 2007	TSS	Monthly	mg/l	12	90
October 2007	TSS	Weekly	mg/l	18	90
October 2007	TSS	Monthly	kg/day	1.0	1.8
October 2007	TSS	Weekly	kg/day	1.5	1.8
October 2007	Ammonia	Monthly	mg/l	1.0	1.1
October 2007	Fecal Coliform	Monthly	#/100ml	1000	60000
October 2007	Fecal Coliform	Weekly	#/100ml	2000	60000
October 2007	CBOD5	Monthly	mg/l	10	22
October 2007	CBOD5	Weekly	mg/l	15	22
November 2007	TSS	Monthly	mg/l	12	13
December 2007	TSS	Monthly	mg/l	12	13
January 2008	Ammonia	Monthly	mg/l	3.0	5.1
January 2008	Ammonia	Weekly	mg/l	4.5	5.1
January 2008	CBOD5	Monthly	mg/l	10	11
February 2008	TSS	Monthly	mg/l	12	42
February 2008	TSS	Weekly	mg/l	18	42

Ms. Kyra Hornsby
April 24, 2008
Page 2

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
February 2008	Ammonia	Monthly	mg/l	3.0	13
February 2008	Ammonia	Weekly	mg/l	4.5	13
February 2008	CBOD5	Monthly	mg/l	10	32
February 2008	CBOD5	Weekly	mg/l	15	32

Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



Ned Sarle
Division of Surface Water
Permit Section

cc: Frank Shuler, BHE Environmental