



Environmental
Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PT0007920090108

BUTLER

GOLDEN YEARS HEALTHCARE WWTP

SARLE, EDWARD

2009/01/08

Sewage



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 8, 2009

Ms. Kyra Hornsby
CHS Oxford Inc.
2436 Old Oxford Road
Hamilton, Ohio 45013

Re: Butler County, Golden Years Healthcare, NPDES Permit Violations


Dear Ms. Hornsby:

We have reviewed your Monthly Operating Reports covering the months of July through November 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0118397; OEPA Permit # 1PT00079*CD). The specific instances of noncompliance were as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
September 2008	TSS	Monthly	mg/l	12	13
October 2008	TSS	Monthly	mg/l	12	29
October 2008	Fecal Coliform	Monthly	#/100ml	1000	2800
October 2008	TSS	Weekly	mg/l	18	29
October 2008	Fecal Coliform	Weekly	#/100ml	2000	2800
October 2008	DO	Daily	mg/l	6.0	5.8
November 2008	TSS	Monthly	mg/l	12	113
November 2008	CBOD5	Monthly	mg/l	10	15
November 2008	TSS	Weekly	mg/l	18	113

Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."



Ms. Kyra Hornsby
January 8, 2009
Page 2

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

A handwritten signature in black ink, appearing to read "Ned Sarle", with a long horizontal flourish extending to the right.

Ned Sarle
Division of Surface Water
Permit Section

cc: Frank Shuler, BHE Environmental

