



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korteski, Director



1PT0007920110217

BUTLER

GOLDEN YEARS HEALTHCARE WWTP

SARLE, EDWARD

2011/02/17



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 17, 2011

Ms. Kyra Hornsby
CHS Oxford Inc.
2436 Old Oxford Road
Hamilton, Ohio 45013

Re: Butler County, Golden Years Healthcare, NPDES Permit Violations

Dear Ms. Hornsby:

We have reviewed your Monthly Operating Reports covering the months of September 2010 through January 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0118397; OEPA Permit # 1PT00079*CD). The specific instances of noncompliance were as follows:

Effluent Limit Violations for September 2010 through January 2011					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
January 2011	TSS	Monthly	mg/l	12	24
January 2011	TSS	Weekly	mg/l	18	24
January 2011	CBOD5	Monthly	mg/l	10	11

We noted in our last Notice of Violation letter our concerns about these NPDES Permit violations. In the past, detailed plans for constructing a new tertiary and disinfection treatment system had been prepared by Golden Years. These plans were placed on hold when the WWTP operations improved and the effluent limit violations were eliminated. However, these effluent violations have continued. Golden Years must proceed with constructing these WWTP improvements.

Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions

Ms. Kyra Hornsby
February 17, 2011
Page 2

taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



Ned Sarle
Division of Surface Water
Permit Section

cc: Frank Shuler, BHE Environmental
Greg Ross, Winelco, Inc.