



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1B0000820091202

BUTLER

HAMILTON MUNICIPAL ELECTRIC PLANT *

SARLE, EDWARD

2009/12/02

Sewage



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

December 2, 2009

Mr. Dan Moats
City of Hamilton
345 High Street
Hamilton, Ohio 45011

Re: ~~Butler County, Hamilton Municipal Electric Plant~~ NPDES Permit Violations

Dear Mr. Moats:

We have received your Monthly Operating Reports covering the months of February through October 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0010413; OEPA Permit # 11B00008*JD). The specific instances of noncompliance were as follows:

Effluent Limit Violations for February through October 2009						
Reporting Period	Station	Parameter	Limit Type	Units	Permit Limit	Reported Value
June 2009	005	pH	Daily	S.U.	6.5	5.7
July 2009	006	TSS	Monthly	kg/day	61	62

Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

Ned Sarle
Division of Surface Water
Permit Section

