



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PE0000220080211

BUTLER

HAMILTON WATER RECLAMATION FACILITY

SARLE, EDWARD

2008/02/11

Sewage



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 11, 2008

Mr. Billy Slaven
City of Hamilton
2451 River Road
Hamilton, Ohio 45011

Re: Butler County, Hamilton WWTP, NPDES Permit Violations

Dear Mr. Slaven:

We have reviewed your Monthly Operating Reports covering the months of August through December 2007 for the referenced facility. Our review indicates a violation of the condition of your NPDES Permit (NPDES Permit # OH0025445; OEPA Permit # 1PE00002*KD). The specific instance of noncompliance was as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
October 2007	Chlorine	Daily	mg/l	0.037	0.32

Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reason for the above violation and the action being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

~~Ned Sarle~~
Division of Surface Water
Permit Section

