



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korteski, Director



1PP0000420080109

BUTLER HUESTON WOODS STATE PARK GOLF COURSE SARLE, EDWARD 2008/01/09



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 9, 2008

Mr. Lonnie Snow
Hueston Woods State Park
6301 Park Office Road
College Corner, Ohio 45003

Certified Letter

Re: Butler County, Golf Course WWTP, NPDES Permit Violations

Dear Mr. Snow:

The NPDES Permit for this facility will expire on April 30, 2008. The NPDES Permit required that the renewal application be submitted at least 180 days prior to the expiration date of the permit or by October 31, 2007. At this time, the Ohio EPA has failed to receive the NPDES Permit renewal application. Action must be taken immediately to address this violation. The Ohio Department of Natural Resources must submit the NPDES Permit renewal application as soon as possible but not later than February 8, 2008.

In addition, we have reviewed your Monthly Operating Reports (MORs) covering the months of May 2006 through November 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0037524; OEPA Permit # 1PP00004*AD). The specific instances of noncompliance and deficiencies were as follows:

| Effluent Limit Violations | | | | | |
|---------------------------|----------------|------------|-------|-------|----------------|
| Reporting Period | Parameter | Limit Type | Units | Limit | Reported Value |
| August 2006 | Fecal Coliform | Monthly | mg/l | 1000 | 1700 |
| August 2006 | DO | Daily | mg/l | 6.0 | 3.7 |
| August 2006 | DO | Daily | mg/l | 6.0 | 4.3 |
| August 2006 | DO | Daily | mg/l | 6.0 | 5.5 |
| August 2006 | DO | Daily | mg/l | 6.0 | 5.8 |

| Effluent Monitoring Violations | | | | | |
|--------------------------------|---------|----------------|------------------|----------|----------|
| Reporting Period | Station | Parameter | Sample Frequency | Expected | Reported |
| June 2006 | 001 | TSS | 1/Quarter | 1 | 0 |
| June 2006 | 001 | Ammonia | 1/Quarter | 1 | 0 |
| June 2006 | 001 | Fecal Coliform | 1/Quarter | 1 | 0 |
| June 2006 | 001 | CBOD5 | 1/Quarter | 1 | 0 |
| June 2006 | 001 | Chlorine | 1/Quarter | 1 | 0 |
| June 2006 | 001 | pH | 1/Quarter | 1 | 0 |
| June 2006 | 001 | DO | 1/Quarter | 1 | 0 |
| December 2006 | 001 | TSS | 1/Quarter | 1 | 0 |
| December 2006 | 001 | Ammonia | 1/Quarter | 1 | 0 |
| December 2006 | 001 | CBOD5 | 1/Quarter | 1 | 0 |
| December 2006 | 001 | pH | 1/Quarter | 1 | 0 |
| December 2006 | 001 | DO | 1/Quarter | 1 | 0 |
| March 2007 | 001 | TSS | 1/Quarter | 1 | 0 |
| March 2007 | 001 | Ammonia | 1/Quarter | 1 | 0 |
| March 2007 | 001 | CBOD5 | 1/Quarter | 1 | 0 |
| March 2007 | 001 | pH | 1/Quarter | 1 | 0 |
| March 2007 | 001 | DO | 1/Quarter | 1 | 0 |


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

Mr. Lonnie Snow
January 9, 2008
Page 3

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



Ned Sarle
Division of Surface Water
Permit Section

cc: Ms. Tara Lee, Ohio Department of Natural Resources

