




**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PV0002120070710

BUTLER

ISLAND LAKE MHP WWTP

SARLE, EDWARD

2007/07/10

2 page



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

July 10, 2007

Mr. James Geyer
Island Lake MHP
P.O. Box 354
Oxford, Ohio 45056

Re: Butler County, Island Lake MHP, NPDES Permit Violations

Dear Mr. Geyer:

The Ohio EPA has reviewed your Monthly Operating Reports (MORs) covering the month of March 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0049875; OEPA Permit # 1PV00021*DD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations

Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
March 2007	TSS	Monthly	mg/l	12	62
March 2007	TSS	Weekly	mg/l	18	59
March 2007	TSS	Weekly	mg/l	18	38
March 2007	TSS	Weekly	mg/l	18	168
March 2007	TSS	Weekly	mg/l	18	31
March 2007	TSS	Monthly	kg/day	1.81	7.78
March 2007	TSS	Weekly	kg/day	2.72	21.4
March 2007	TSS	Weekly	kg/day	2.72	4.31
March 2007	TSS	Weekly	kg/day	2.72	9.92
March 2007	CBOD5	Monthly	mg/l	10	15
March 2007	CBOD5	Weekly	mg/l	15	27
March 2007	CBOD5	Weekly	mg/l	15	27
March 2007	CBOD5	Monthly	kg/day	1.51	1.87
March 2007	CBOD5	Weekly	kg/day	2.27	3.70
March 2007	CBOD5	Weekly	kg/day	2.27	3.07



Mr. James Geyer
July 10, 2007
Page 2


The NPDES Permit requires in Part III, Section 4 titled "Reporting" that the MORs be submitted either as a hard copy or as an electronic submission. The MORs are required to be submitted to the Ohio EPA, Central Office. The March 2007 MORs were faxed to the Ohio EPA, Southwest District Office. This method of submission does not comply with the NPDES Permit. The failure to correctly submit the MORs is a violation of the NPDES Permit. These violations are subject to civil penalties of \$700.00 per day per violation.

Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



Ned Sarle
Division of Surface Water
Permit Section

cc: John Phillips, Phillips Law Firm, Inc.
Duane Boswell, WWTP Operator
Gregg Bachmann, Ohio Attorney General Office

