



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PV0002120071015

BUTLER

ISLAND LAKE MHP WWTP

SARLE, EDWARD

2007/10/15

Sewage



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

October 15, 2007

Mr. James Geyer
Island Lake MHP
P.O. Box 354
Oxford, Ohio 45056

Re: Butler County, Island Lake MHP; NPDES Permit Violations

Dear Mr. Geyer:

The Ohio EPA has reviewed your Monthly Operating Reports (MORs) covering the months of June through September 2007 for the referenced facility. Our review indicates a violation of the condition of your NPDES Permit (NPDES Permit # OH0049875; OEPA Permit # 1PV00021*DD). The specific instance of noncompliance and deficiency was as follows:

Effluent Limit Violations

Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
------------------	-----------	------------	-------	--------------	----------------

September 2007	Fecal Coliform	Monthly	#/100ml	1000	1100
----------------	----------------	---------	---------	------	------

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violation, as well as a description of the action taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the action. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

