



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PT0008420110809

BUTLER

MADISON LOCAL SCHOOLS WWTP

SARLE, EDWARD

2011/08/09



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 9, 2011

Mr. Curtis Philpot
Madison Local School District
1324 Middletown – Eaton Road
Middletown, Ohio 45042

Re: Butler County, Middletown – Eaton Road Campus, NPDES Permit Violations

Dear Mr. Philpot:

We have reviewed your Discharge Monitoring Reports (DMRs) covering the months of April 2009 through June 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0123251; OEPA Permit # 1PT00084*CD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations for April 2009 through June 2011					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
May 2011	Ammonia	Monthly	mg/l	1.0	1.67
May 2011	Ammonia	Weekly	mg/l	1.5	1.67
May 2011	Ammonia	Monthly	kg/day	0.09	0.12

Please be advised that failure to comply with the effluent limitations or to satisfy the reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

Mr. Curtis Philpot
August 9, 2011
Page 2

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

A handwritten signature in black ink, appearing to read "Ned Sarle", with a long horizontal flourish extending to the right.

Ned Sarle
Division of Surface Water
Permit Section

cc: Matt Fraley, Streamborn Environmental Services, Inc.