



Environmental  
Protection Agency

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director



\*1PV0012420090120\*

BUTLER

MILLVILLE MHP

SARLE, EDWARD

2009/01/20

Sewage



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 20, 2009

Mr. James Geyer, Owner  
JGR Properties, Inc.  
P.O. Box 354  
Oxford, Ohio 45056

Re: Butler County, Millville MHP, NPDES Permit Violations

Dear Mr. Geyer:

We have reviewed your Monthly Operating Reports (MORs) covering the month of December 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0133736; OEPA Permit # 1PV00124\*BD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Limit	Reported Value
December 2008	CBOD5	Monthly	mg/l	10	99
December 2008	CBOD5	Monthly	kg/day	0.11	1.4
December 2008	CBOD5	Weekly	mg/l	15	99
December 2008	CBOD5	Weekly	kg/day	0.17	1.4
December 2008	DO	Daily	mg/l	6.0	4.5
December 2008	Ammonia	Monthly	mg/l	3.0	26
December 2008	Ammonia	Monthly	kg/day	0.034	0.37
December 2008	Ammonia	Weekly	mg/l	4.5	26
December 2008	Ammonia	Weekly	kg/day	0.051	0.37
December 2008	pH	Daily	S.U.	6.5	4.5
December 2008	TSS	Monthly	mg/l	12	173
December 2008	TSS	Monthly	kg/day	0.14	2.5
December 2008	TSS	Weekly	mg/l	18	173
December 2008	TSS	Weekly	kg/day	0.20	2.5

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.




Mr. James Geyer  
January 20, 2009  
Page 2

We have received your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Your explanation is not satisfactory and we request, within ten days of receipt of this letter, written information as to what additional steps you take to prevent further occurrences. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

A handwritten signature in black ink, appearing to read "Ned Sarle", with a long horizontal flourish extending to the right.

Ned Sarle  
Division of Surface Water  
Permit Section

