



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PT0009820071120

BUTLER

MORGAN ELEM SCH

POHLMAN, LAURA

2007/11/20



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 20, 2007

Mr. Todd Yohey, Superintendent
Ross Local School District
3371 Hamilton Cleves Road
Hamilton, Ohio 45013

Re: Butler County, Morgan Elementary School, NPDES Permit Violations

Dear Mr. Yohey:

We have reviewed your Monthly Operating Reports (MORs) covering the months of July through September 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0127558; OEPA Permit # 1PT00098*AD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations

Reporting Period	Parameter	Limit Type	Limit	Reported Value
August 2007	Chlorine, Total Residu	1D Conc	0.019	.06

Numerous monitoring violations were noted for the Turbidity, Color, and Odor. This parameter must be monitored and reported on a daily basis.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

Mr. Todd Yohey
November 20, 2007
Page 2

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,


Laura Pohlman
Division of Surface Water
Permit Section

cc: Tom Perry. Morgan Elementary School
Hyden Smith Morgan Elementary School